

# Water Testing Results - Alameda Elementary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Room #	Fixture ID #	Date Tested	Test Results
Classroom 1 Faucet	1	21080200-001CF23A	2/22/2023	2.86
Classroom 1 Drinking Fountain	1	21080200-002DW23A	2/22/2023	1.76
Classroom 2 Faucet	2	21080200-003CF23A	2/22/2023	5.97
Classroom 2 Drinking Fountain	2	21080200-004DW23A	2/22/2023	4.17
Classroom 3 Faucet	3	21080200-005CF23A	2/22/2023	4.85
Classroom 3 Drinking Fountain	3	21080200-006DW23A	2/22/2023	5.57
Classroom 4 Faucet	4	21080200-007CF23A	2/22/2023	3.65
Classroom 4 Drinking Fountain	4	21080200-008DW23A	2/22/2023	3.87
Classroom 5 Faucet	5	21080200-009CF23A	2/22/2023	ND
Classroom 5 Drinking Fountain	5	21080200-010DW23A	2/22/2023	ND
Classroom 6 Faucet	6	21080200-011CF23A	2/22/2023	1.39
Classroom 6 Drinking Fountain	6	21080200-012DW23A	2/22/2023	ND
Classroom 7 Faucet	7	21080200-013CF23A	2/22/2023	1.76
Classroom 7 Drinking Fountain	7	21080200-014DW23A	2/22/2023	ND
Classroom 8 Faucet	8	21080200-015CF23A	2/22/2023	2.55
Classroom 8 Drinking Fountain	8	21080200-016DW23A	2/22/2023	ND
Classroom 9 Faucet	9	21080200-017CF23A	2/22/2023	1.35
Classroom 9 Drinking Fountain	9	21080200-018DW23A	2/22/2023	ND
Classroom 10 Faucet	10	21080200-019CF23A	2/22/2023	1.99
Classroom 10 Drinking Fountain	10	21080200-020DW23A	2/22/2023	ND
Classroom 11 Faucet	11	21080200-021CF23A	2/22/2023	3.65
Classroom 11 Drinking Fountain	11	21080200-022DW23A	2/22/2023	5.51
Classroom 12 Faucet	12	21080200-023CF23A	2/22/2023	1.26
Classroom 12 Drinking Fountain	12	21080200-024DW23A	2/22/2023	1
Classroom 14 Faucet	14	21080200-025CF23A	2/22/2023	6.64
Classroom 14 Drinking Fountain	14	21080200-026DW23A	2/22/2023	4.32
Classroom 16 Faucet	16	21080200-027CF23A	2/22/2023	15.9

Classroom 16 Drinking Fountain	16	21080200-028DW23A	2/22/2023	1.34
Classroom 17 Faucet	17	21080200-029CF23A	2/22/2023	3.18
Classroom 17 Drinking Fountain	17	21080200-030DW23A	2/22/2023	3.61
Classroom 18 Faucet	18	21080200-031CF23A	2/22/2023	3.17
Classroom 18 Drinking Fountain	18	21080200-032DW23A	2/22/2023	3.65
Classroom 19 Faucet	19	21080200-033CF23A	2/22/2023	5.86
Classroom 19 Drinking Fountain	19	21080200-034DW23A	2/22/2023	6.5
Classroom 20 Faucet	20	21080200-035CF23A	2/22/2023	16.6
Classroom 20 Drinking Fountain	20	21080200-036DW23A	2/22/2023	8.75
Classroom 21 Faucet	21	21080200-037CF23A	2/22/2023	3.7
Classroom 21 Drinking Fountain	21	21080200-038DW23A	2/22/2023	6.49
Classroom 22 Faucet	22	21080200-039CF23A	2/22/2023	3.33
Classroom 22 Drinking fountain	22	21080200-040DW23A	2/22/2023	4.75
Kitchen Hand Washing Faucet	26	21080200-041SF23A	2/22/2023	6.83
Kitchen Left Faucet	26	21080200-042KF23A	2/22/2023	1.32
Kitchen Center Faucet	26	21080200-043KF23A	2/22/2023	ND
Kitchen Right Faucet	26	21080200-044KF23A	2/22/2023	3.04
Classroom 28 Faucet	28	21080200-045KF23A	2/22/2023	12.8
Staff Room Faucet	34	21080200-46KF23A	2/22/2023	4.45
Northwest Restroom Left Faucet	35	21080200-047BF23A	2/22/2023	3.42
Northwest Restroom Right Faucet	35	21080200-048BF23A	2/22/2023	2.7
Northeast Restroom Left Faucet	36	21080200-049BF23A	2/22/2023	2.22
Northeast Restroom Right Faucet	36	21080200-050BF23A	2/22/2023	3.26
Northeast Gym Restroom Left Faucet	37	21080200-051BF23A	2/22/2023	3.91
Northeast Gym Restroom Right Faucet	37	21080200-052BF23A	2/22/2023	3.94
Northwest Gym Restroom Left Faucet	38	21080200-053BF23A	2/22/2023	2.89
Northwest Gym Restroom Right Faucet	38	21080200-054BF23A	2/22/2023	3.52
East Bathroom Left Faucet	43	21080200-055BF23A	2/22/2023	3.6
East Bathroom Right Faucet	44	21080200-056BF23A	2/22/2023	3.59
Main Office Restroom Faucet	45	21080200-057BF23A	2/22/2023	4
Center Left Drinking Fountain	46	21080200-058DW23A	2/22/2023	1.26
Center Right Drinking Fountain	46	21080200-059DW23A	2/22/2023	1.27
South Restroom Left Faucet	47	21080200-060BF23A	2/22/2023	ND
South Restroom Right Faucet	48	21080200-061BF23A	2/22/2023	1.87

South Staff Restroom Faucet	49	21080200-062BF23A	2/22/2023	ND
South Entry Left Drinking Fountain		21080200-063DW23A	2/22/2023	ND
South Entry Right Drinking Fountain		21080200-064DW23A	2/22/2023	ND
Northwest Gym Bottle Filler		21080200-065WB23A	2/22/2023	3.01
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing				
<b>RETESTS</b>				
Classroom 16 Faucet	16	21080200-027CF23B	4/4/2023	9
Classroom 20 faucet	20	21080200-035CF23B	4/4/2023	7.09
Classroom 28 Faucet	16	21080200-045CF23	12/13/2023	1.2
ND = Non Detect - Lead level is below the set detection limits of 1 ppb				