

Water Testing Results - Cairo Elementary
Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Room #	Fixture ID #	Date Tested	Test Results
Classroom 0 Faucet	0	21080300-001CF23A	2/28/2023	4.3
Classroom 0 Drinking Fountain	0	21080300-002DW23A	2/28/2023	4.04
East Boys Restroom	39	21080300-003BF23A	2/28/2023	5.38
East Girls Restroom	37	21080300-004BF23A	2/28/2023	5.16
Classroom 1 Faucet	1	21080300-005CF23A	2/28/2023	3.82
Classroom 1 Drinking Fountain	1	21080300-006DW23A	2/28/2023	3.98
Classroom 2 Faucet	2	21080300-007CF23A	2/28/2023	4.18
Classroom 2 Drinking Fountain	2	21080300-008DW23A	2/28/2023	5.36
South Boys Restroom	36	21080300-009BF23A	2/28/2023	7.39
Outside Drinking Fountain	36	21080300-010DW23A		
Classroom 3 Faucet	3	21080300-011CF23A	2/28/2023	7.49
Classroom 3 Drinking Fountain	3	21080300-012DW23A	2/28/2023	4.81
Classroom 4 Faucet	4	21080300-013CF23A	2/28/2023	6
Classroom 4 Drinking Fountain	4	21080300-014DW23A	2/28/2023	1.74
South Girls Restroom	34	21080300-015BF23A	2/28/2023	6.01
Classroom 5 Faucet	5	21080300-016CF23A	2/28/2023	3.06
Classroom 5 Drinking Fountain	5	21080300-017DW23A	2/28/2023	3.8
Staff Room Faucet	6	21080300-018KF23A	2/28/2023	3.75
Office Left Bathroom Faucet	30	21080300-019BF23A	2/28/2023	2.98
Office Right Bathroom Faucet	31	21080300-020BF23A	2/28/2023	2.76
Classroom 15 Faucet	15	21080300-021CF23A	2/28/2023	3.5
Kitchen Left Faucet	24	21080300-022KF23A	2/28/2023	155
Kitchen Center Faucet	24	21080300-023KF23A	2/28/2023	30.6
Kitchen Right Faucet	24	21080300-024KF23A	2/28/2023	5.84
Kitchen Hand Wash Faucet	24	21080300-025SF23A	2/28/2023	13.9
South Gym Drinking Fountain	25	21080300-026DW23A	2/28/2023	6.17
Main Entry Faucet	Entry	21080300-027RF23A	2/28/2023	3.62
Main Entry Left Drinking Fountain	Entry	21080300-028DW23A	2/28/2023	4.68
Main Entry Right Drinking Fountain	Entry	21080300-029DW23A	2/28/2023	2.37

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS				
Kitchen Left Faucet	24	21080300-022KF23B	4/4/2023	8.5
Kitchen Center Faucet	24	21080300-023KF23B	4/4/2023	5.6
Kitchen Hand Wash Faucet	24	21080300-025SF23B	4/4/2023	4.5

ND = Non Detect - Lead level is below the set detection limits of 1 ppb