

LAB FEDERAL ID#: ID00013	
DATE RECEIVED: 11/23/2016	DATE REPORTED BY LAB: 12/13/2016
COMPLIANCE SAMPLE: YES	REPLACEMENT SAMPLE: NO
SAMPLE TYPE:	
PWS #:	PWS NAME: ONTARIO SCHOOL DISTRICT 8C
CONTACT NAME: TABLE ROCK ANALYTICAL LAB	CONTACT PHONE: 541-235-4006



## Anatek Labs, Inc.

1282 Alturas Drive  
 Moscow, ID 83843  
 (208) 883-2839  
 FAX 882-9246  
 moscow@anateklabs.com

504 E. Sprague Ste. D  
 Spokane, WA 99202  
 (509) 838-3999  
 FAX 838-4433  
 spokane@anateklabs.com

www.anateklabs.com

### Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
161128031-001	161121L1 / OSD-AI-25A-FP	11/21/2016 5:12 AM	Lead	0.00715	EPA 200.8	12/6/2016	HSW	
161128031-002	161121L2 / OSD-AL-12A-CRHW	11/21/2016 5:05 AM	Lead	0.00752	EPA 200.8	12/6/2016	HSW	
161128031-003	161121L3 / OSD-AL-12B-CRDF	11/21/2016 5:05 AM	Lead	0.00804	EPA 200.8	12/6/2016	HSW	
161128031-004	161121L4 / OSD-AL-20A-CRHW	11/21/2016 5:07 AM	Lead	0.00457	EPA 200.8	12/6/2016	HSW	
161128031-005	161121L5 / OSD-CA-1A-CRHW	11/21/2016 4:45 AM	Lead	0.00970	EPA 200.8	12/6/2016	HSW	
161128031-006	161121L6 / OSD-CA-2A-CRHW	11/21/2016 4:46 AM	Lead	0.00819	EPA 200.8	12/6/2016	HSW	
161128031-007	161121L7 / OSD-CA-3A-CRHW	11/21/2016 4:47 AM	Lead	0.0384	EPA 200.8	12/6/2016	HSW	
161128031-008	161121L8 / OSD-CA-24A-FP	11/21/2016 4:48 AM	Lead	0.00802	EPA 200.8	12/6/2016	HSW	
161128031-009	161121L9 / OSD-CA-24B-FP	11/21/2016 4:48 AM	Lead	0.00339	EPA 200.8	12/6/2016	HSW	
161128031-010	161121L10 / OSD-CA-24-HW	11/21/2016 4:49 AM	Lead	0.00919	EPA 200.8	12/6/2016	HSW	
161128031-011	161121L11 / OSD-CA-31-RRHW	11/21/2016 4:50 AM	Lead	0.0102	EPA 200.8	12/6/2016	HSW	
161128031-012	161121L12 / OSD-MR-114A-CRH	11/21/2016 5:30 AM	Lead	ND	EPA 200.8	12/6/2016	HSW	
161128031-013	161121L13 / OSD-MR-114B-CRDF	11/21/2016 5:30 AM	Lead	0.00419	EPA 200.8	12/6/2016	HSW	
161128031-014	161121L14 / OSD-MR-213C-RRH	11/21/2016 5:32 AM	Lead	0.00133	EPA 200.8	12/8/2016	HSW	
161128031-015	161121L15 / OSD-MR-214B-RRH	11/21/2016 5:33 AM	Lead	0.00652	EPA 200.8	12/8/2016	HSW	
161128031-016	161121L16 / OSD-MR-214C-RRH	11/21/2016 5:33 AM	Lead	ND	EPA 200.8	12/8/2016	HSW	
161128031-017	161121L17 / OSD-MR-312A-CRH	11/21/2016 5:35 AM	Lead	0.00241	EPA 200.8	12/8/2016	HSW	
161128031-018	161121L18 / OSD-PI-2A-CRHW	11/21/2016 4:15 AM	Lead	0.00746	EPA 200.8	12/8/2016	HSW	
161128031-019	161121L19 / OSD-PI-4B-CRDF	11/21/2016 4:16 AM	Lead	0.00425	EPA 200.8	12/8/2016	HSW	
161128031-020	161121L20 / OSD-PI-6B-CRDF	11/21/2016 4:17 AM	Lead	0.00255	EPA 200.8	12/8/2016	HSW	
161128031-021	161121L21 / OSD-HS-812-DF	11/21/2016 6:18 AM	Lead	0.0120	EPA 200.8	12/8/2016	HSW	
161128031-022	161121L22 / OSD-HS-430B-CRHW	11/21/2016 6:20 AM	Lead	ND	EPA 200.8	12/8/2016	HSW	

**Comments:**

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595  
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

LAB FEDERAL ID#: ID00013	
DATE RECEIVED: 11/23/2016	DATE REPORTED BY LAB: 12/13/2016
COMPLIANCE SAMPLE: YES	REPLACEMENT SAMPLE: NO
SAMPLE TYPE:	
PWS #:	PWS NAME: ONTARIO SCHOOL DISTRICT 8C
CONTACT NAME: TABLE ROCK ANALYTICAL LAB	CONTACT PHONE: 541-235-4006



## Anatek Labs, Inc.

1282 Alturas Drive  
Moscow, ID 83843  
(208) 883-2839  
FAX 882-9246  
moscow@anateklabs.com

504 E. Sprague Ste. D  
Spokane, WA 99202  
(509) 838-3999  
FAX 838-4433  
spokane@anateklabs.com

www.anateklabs.com

### Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
161128031-023	161121L23 / OSD-MS-311B-RRHW	11/21/2016 6:07 AM	Lead	0.00177	EPA 200.8	12/8/2016	HSW	
161128031-024	161121L24 / OSD-MS-B48-RRHW	11/21/2016 5:58 AM	Lead	0.00497	EPA 200.8	12/8/2016	HSW	
161128031-025	161121L25 / OSD-MS-002A-CRHW	11/21/2016 6:02 AM	Lead	0.00250	EPA 200.8	12/8/2016	HSW	

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L.

MDL (Method Detection Limit) is 0.001 mg/L for Lead.

ND = Analyte Not Detected

All results in mg/L unless otherwise noted.


This report shall not be reproduced except in full, without the written approval of the laboratory.

The results reported relate only to the samples indicated.

Soil/solid results are reported on a dry-weight basis unless otherwise noted.

TABLE ROCK ANALYTICAL LAB  
ONTARIO SCHOOL DISTRICT 8C  
195 SW 3RD AVE  
ONTARIO, OR 97914

Authorized Signature

  
Todd Taruscio, Lab Manager

#### Comments:

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT.CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595  
Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT.Cert0095; FL(NELAP): E871099

Tuesday, December 13, 2016

Page 2 of 2