

|   |                                      |
|---|--------------------------------------|
| LAB FEDERAL ID#: ID00013                |                                      |
| DATE RECEIVED: 8/17/2016                | DATE REPORTED BY LAB: 9/9/2016       |
| COMPLIANCE SAMPLE: YES                  | REPLACEMENT SAMPLE: NO               |
| SAMPLE TYPE:                            |                                      |
| PWS #:                                  | PWS NAME: ONTARIO SCHOOL DISTRICT 8C |
| CONTACT NAME: TABLE ROCK ANALYTICAL LAB | CONTACT PHONE: 541-235-4006          |



**Anatek Labs, Inc.**

1282 Alturas Drive  
 Moscow, ID 83843  
 (208) 883-2839  
 FAX 882-9246  
 moscow@anateklabs.com

504 E. Sprague Ste. D  
 Spokane, WA 99202  
 (509) 838-3999  
 FAX 838-4433  
 spokane@anateklabs.com

www.anateklabs.com

**Lead Analysis Report**

| Lab Sample #  | Sample Location              | Collection Date / Time | Analyte | Result  | Method    | Analysis Date | Analyst | Qualifier |
|---------------|------------------------------|------------------------|---------|---------|-----------|---------------|---------|-----------|
| 160818002-001 | 160815A1 / OSD-MR-103A-CRHW  | 8/11/2016 2:20 PM      | Lead    | 0.00309 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-002 | 160815A2 / OSD-MR-103B-CRDF  | 8/11/2016 2:25 PM      | Lead    | ND      | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-003 | 160815A3 / OSD-MR-104A-HW    | 8/11/2016 2:28 PM      | Lead    | 0.00200 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-004 | 160815A4 / OSD-MR-104B-DF    | 8/11/2016 2:32 PM      | Lead    | ND      | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-005 | 160815A5 / OSD-MR-104C-DF    | 8/11/2016 2:32 PM      | Lead    | ND      | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-006 | 160815A6 / OSD-MR-107A-CRHW  | 8/11/2016 2:36 PM      | Lead    | 0.00269 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-007 | 160815A7 / OSD-MR-107B-CRDF  | 8/11/2016 2:36 PM      | Lead    | 0.00262 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-008 | 160815A8 / OSD-MR-108A-CRHW  | 8/11/2016 2:40 PM      | Lead    | 0.00439 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-009 | 160815A9 / OSD-MR-108B-CRDF  | 8/11/2016 2:40 PM      | Lead    | 0.00105 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-010 | 160815A10 / OSD-MR-316A-RRH  | 8/11/2016 4:19 PM      | Lead    | 0.00120 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-011 | 160815A11 / OSD-MR-109A-CRH  | 8/11/2016 2:44 PM      | Lead    | 0.00202 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-012 | 160815A12 / OSD-MR-109B-CRDF | 8/11/2016 2:44 PM      | Lead    | ND      | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-013 | 160815A13 / OSD-MR-110A-CRH  | 8/11/2016 2:47 PM      | Lead    | 0.00300 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-014 | 160815A14 / OSD-MR-110B-CRDF | 8/11/2016 2:47 PM      | Lead    | ND      | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-015 | 160815A15 / OSD-MR-113A-CRH  | 8/11/2016 3:04 PM      | Lead    | 0.00309 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-016 | 160815A16 / OSD-MR-113B-CRDF | 8/11/2016 3:04 PM      | Lead    | 0.00360 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-017 | 160815A17 / OSD-MR-114A-CRH  | 8/11/2016 3:00 PM      | Lead    | 0.0157  | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-018 | 160815A18 / OSD-MR-114B-CRDF | 8/11/2016 3:00 PM      | Lead    | 0.0296  | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-019 | 160815A19 / OSD-MR-118A-CRH  | 8/11/2016 2:58 PM      | Lead    | 0.00709 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-020 | 160815A20 / OSD-MR-118B-CRDF | 8/11/2016 2:58 PM      | Lead    | 0.00304 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-021 | 160815A21 / OSD-MR-119A-CRH  | 8/11/2016 2:55 PM      | Lead    | 0.00453 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-022 | 160815A22 / OSD-MR-119B-CRDF | 8/11/2016 2:55 PM      | Lead    | 0.00492 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-023 | 160815A23 / OSD-MR-120A-CRH  | 8/11/2016 2:52 PM      | Lead    | 0.00408 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-024 | 160815A24 / OSD-MR-120B-CRDF | 8/11/2016 2:52 PM      | Lead    | 0.00366 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-025 | 160815A25 / OSD-MR-121A-CRH  | 8/11/2016 2:50 PM      | Lead    | 0.00415 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-026 | 160815A26 / OSD-MR-201A-CRH  | 8/11/2016 3:14 PM      | Lead    | 0.00462 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-027 | 160815A27 / OSD-MR-201B-CRDF | 8/11/2016 3:14 PM      | Lead    | 0.00243 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-028 | 160815A28 / OSD-MR-202A-CRH  | 8/11/2016 3:11 PM      | Lead    | 0.00493 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-029 | 160815A29 / OSD-MR-202B-CRDF | 8/11/2016 3:11 PM      | Lead    | 0.00202 | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-030 | 160815A30 / OSD-MR-213A-RRH  | 8/11/2016 3:54 PM      | Lead    | ND      | EPA 200.8 | 9/2/2016      | HSW     |           |
| 160818002-031 | 160815A31 / OSD-MR-213B-RRH  | 8/11/2016 3:54 PM      | Lead    | 0.00157 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-032 | 160815A32 / OSD-MR-213C-RRH  | 8/11/2016 3:58 PM      | Lead    | 0.0113  | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-033 | 160815A33 / OSD-MR-214B-RRH  | 8/11/2016 3:52 PM      | Lead    | 0.00132 | EPA 200.8 | 9/5/2016      | HSW     |           |

**Comments:**

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595  
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

|                           |                            |                |
|---------------------------|----------------------------|----------------|
| LAB FEDERAL ID#:          |                            | ID00013        |
| DATE RECEIVED:            | DATE REPORTED BY LAB:      |                |
| 8/17/2016                 | 9/9/2016                   |                |
| COMPLIANCE SAMPLE: YES    | REPLACEMENT SAMPLE: NO     |                |
| SAMPLE TYPE:              |                            |                |
| PWS #:                    | PWS NAME:                  |                |
|                           | ONTARIO SCHOOL DISTRICT 8C |                |
| CONTACT NAME:             |                            | CONTACT PHONE: |
| TABLE ROCK ANALYTICAL LAB |                            | 541-235-4006   |



**Anatek Labs, Inc.**

1282 Alturas Drive  
 Moscow, ID 83843  
 (208) 883-2839  
 FAX 882-9246  
 moscow@anateklabs.com

504 E. Sprague Ste. D  
 Spokane, WA 99202  
 (509) 838-3999  
 FAX 838-4433  
 spokane@anateklabs.com

www.anateklabs.com

### Lead Analysis Report

| Lab Sample #  | Sample Location              | Collection Date / Time | Analyte | Result  | Method    | Analysis Date | Analyst | Qualifier |
|---------------|------------------------------|------------------------|---------|---------|-----------|---------------|---------|-----------|
| 160818002-034 | 160815A34 / OSD-MR-214C-RRH  | 8/11/2016 3:58 PM      | Lead    | 0.0385  | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-035 | 160815A35 / OSD-MR-203A-CRH  | 8/11/2016 3:18 PM      | Lead    | 0.00194 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-036 | 160815A36 / OSD-MR-203B-CRDF | 8/11/2016 3:18 PM      | Lead    | ND      | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-037 | 160815A37 / OSD-MR-204A-CRH  | 8/11/2016 3:22 PM      | Lead    | 0.00273 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-038 | 160815A38 / OSD-MR-204B-CRDF | 8/11/2016 3:22 PM      | Lead    | ND      | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-039 | 160815A39 / OSD-MR-205A-CRH  | 8/11/2016 3:26 PM      | Lead    | 0.00124 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-040 | 160815A40 / OSD-MR-205B-CRDF | 8/11/2016 3:26 PM      | Lead    | 0.00598 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-041 | 160815A41 / OSD-MR-206A-CRH  | 8/11/2016 3:29 PM      | Lead    | 0.00119 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-042 | 160815A42 / OSD-MR-207A-CRH  | 8/11/2016 3:31 PM      | Lead    | 0.00170 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-043 | 160815A43 / OSD-MR-207B-CRDF | 8/11/2016 3:31 PM      | Lead    | ND      | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-044 | 160815A44 / OSD-MR-208A-CRH  | 8/11/2016 3:34 PM      | Lead    | 0.00167 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-045 | 160815A45 / OSD-MR-208B-CRDF | 8/11/2016 3:34 PM      | Lead    | ND      | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-046 | 160815A46 / OSD-MR-216A-DF   | 8/11/2016 3:40 PM      | Lead    | 0.00669 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-047 | 160815A47 / OSD-MR-216B-DF   | 8/11/2016 3:40 PM      | Lead    | 0.00355 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-048 | 160815A48 / OSD-MR-217A-RRH  | 8/11/2016 3:36 PM      | Lead    | 0.00240 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-049 | 160815A49 / OSD-MR-217B-RRH  | 8/11/2016 3:36 PM      | Lead    | 0.00243 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-050 | 160815A50 / OSD-MR-218A-RRH  | 8/11/2016 3:43 PM      | Lead    | 0.00355 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-051 | 160815A51 / OSD-MR-218B-RRH  | 8/11/2016 3:43 PM      | Lead    | 0.00230 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-052 | 160815A52 / OSD-MR-209A-CRH  | 8/11/2016 3:46 PM      | Lead    | ND      | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-053 | 160815A53 / OSD-MR-209B-CRDF | 8/11/2016 3:46 PM      | Lead    | 0.00232 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-054 | 160815A54 / OSD-MR-210A-CRH  | 8/11/2016 3:50 PM      | Lead    | 0.00503 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-055 | 160815A55 / OSD-MR-210B-CRDF | 8/11/2016 3:50 PM      | Lead    | ND      | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-056 | 160815A56 / OSD-MR-303A-RRH  | 8/11/2016 4:06 PM      | Lead    | 0.00117 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-057 | 160815A57 / OSD-MR-308A-FP   | 8/11/2016 4:10 PM      | Lead    | ND      | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-058 | 160815A58 / OSD-MR-310A-DF   | 8/11/2016 4:20 PM      | Lead    | 0.00523 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-059 | 160815A59 / OSD-MR-312A-CRH  | 8/11/2016 4:10 PM      | Lead    | 0.0315  | EPA 200.8 | 9/8/2016      | HSW     |           |
| 160818002-060 | 160815A60 / OSD-MR-312B-CRDF | 8/11/2016 4:10 PM      | Lead    | 0.00127 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-061 | 160815A61 / OSD-MR-315A-RRH  | 8/11/2016 4:15 PM      | Lead    | 0.00163 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-062 | 160815A62 / OSD-MR-309A-HW   | 8/12/2016 4:57 AM      | Lead    | 0.00226 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-063 | 160815A63 / OSD-MR-309C-FP   | 8/12/2016 4:57 AM      | Lead    | ND      | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-064 | 160815A64 / OSD-MR-111A-RRH  | 8/12/2016 5:25 AM      | Lead    | 0.00885 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-065 | 160815A65 / OSD-MR-111B-RRH  | 8/12/2016 5:25 AM      | Lead    | 0.00544 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-066 | 160815A66 / OSD-MR-111C-RRH  | 8/12/2016 5:25 AM      | Lead    | 0.00576 | EPA 200.8 | 9/5/2016      | HSW     |           |

**Comments:**

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0026; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595  
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

|   |                                      |
|---|--------------------------------------|
| LAB FEDERAL ID#: ID00013                |                                      |
| DATE RECEIVED: 8/17/2016                | DATE REPORTED BY LAB: 9/9/2016       |
| COMPLIANCE SAMPLE: YES                  | REPLACEMENT SAMPLE: NO               |
| SAMPLE TYPE:                            |                                      |
| PWS #:                                  | PWS NAME: ONTARIO SCHOOL DISTRICT 8C |
| CONTACT NAME: TABLE ROCK ANALYTICAL LAB | CONTACT PHONE: 541-235-4006          |



**Anatek Labs, Inc.**

1282 Alturas Drive  
 Moscow, ID 83843  
 (208) 883-2839  
 FAX 882-9246  
 moscow@anateklabs.com

504 E. Sprague Ste. D  
 Spokane, WA 99202  
 (509) 838-3999  
 FAX 838-4433  
 spokane@anateklabs.com

www.anateklabs.com

**Lead Analysis Report**

| Lab Sample #  | Sample Location             | Collection Date / Time | Analyte | Result  | Method    | Analysis Date | Analyst | Qualifier |
|---------------|-----------------------------|------------------------|---------|---------|-----------|---------------|---------|-----------|
| 160818002-067 | 160815A67 / OSD-MR-111D-RRH | 8/12/2016 5:25 AM      | Lead    | 0.00167 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-068 | 160815A68 / OSD-MR-111E-RRH | 8/12/2016 5:25 AM      | Lead    | 0.00574 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-069 | 160815A69 / OSD-MR-112A-RRH | 8/12/2016 5:30 AM      | Lead    | 0.00708 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-070 | 160815A70 / OSD-MR-112B-RRH | 8/12/2016 5:30 AM      | Lead    | 0.00909 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-071 | 160815A71 / OSD-MR-112C-RRH | 8/12/2016 5:30 AM      | Lead    | 0.00764 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-072 | 160815A72 / OSD-MR-112D-RRH | 8/12/2016 5:30 AM      | Lead    | 0.00868 | EPA 200.8 | 9/5/2016      | HSW     |           |
| 160818002-073 | 160815A73 / OSD-MR-112E-RRH | 8/12/2016 5:30 AM      | Lead    | 0.00793 | EPA 200.8 | 9/5/2016      | HSW     |           |

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L.

MDL (Method Detection Limit) is 0.001 mg/L for Lead.

ND = Analyte Not Detected

All results in mg/L unless otherwise noted.


This report shall not be reproduced except in full, without the written approval of the laboratory.

The results reported relate only to the samples indicated.

Soil/solid results are reported on a dry-weight basis unless otherwise noted.

TABLE ROCK ANALYTICAL LAB  
 ONTARIO SCHOOL DISTRICT 8C  
 195 SW 3RD AVE  
 ONTARIO, OR 97914

Authorized Signature

  
 Todd Taruscio, Lab Manager

**Comments:**

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595  
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099