

Room description (per the floor plan)	Canister serial #	Date opened	Time opened	Date Closed	Time closed	Type of test D = detector kit	Test results	Square Feet
AD-O1	2621207	2/20/2018	8:00	2/23/2018	7:27	D	1.1 pCi/L	77
AD-O1	2618428	2/20/2018	8:00	2/23/2018	7:27	Duplicate	1.1 pCi/L	
AD-O2	2621357	2/20/2018	8:01	2/23/2018	7:29	D	0.8 pCi/L	117
AD-O3	2621306	2/20/2018	8:01	2/23/2018	7:29	D	1.0 pCi/L	117
AD-O4	2622221	2/20/2018	8:02	2/23/2018	7:34	D	0.7 pCi/L	115
AD-O5	2618422	2/20/2018	8:03	2/23/2018	7:35	D	1.1 pCi/L	113
AD-CONF-6	2618590	2/20/2018	8:01	2/23/2018	7:23	D	1.2 pCi/L	183
AD-O8	2621369	2/20/2018	8:04	2/23/2018	7:25	D	1.2 pCi/L	1053
AD-O8	2622199	2/20/2018	8:04	2/23/2018	7:25	Duplicate	0.8 pCi/L	
AD-O9	2622225	2/20/2018	8:05	2/23/2018	7:25	D	1.4 pCi/L	115
AD-O10	2622262	2/20/2018	8:05	2/23/2018	7:31	D	1.2 pCi/L	72
AD-O11	2618595	2/20/2018	8:06	2/23/2018	7:31	D	1.4 pCi/L	151
AD-O12	2618608	2/20/2018	8:05	2/23/2018	7:30	D	0.8 pCi/L	369
AD-O13	2618626	2/20/2018	8:10	2/23/2018	7:30	D	0.9 pCi/L	136
AD-O14	2621466	2/20/2018	8:12	2/23/2018	7:29	D	1.2 pCi/L	140
AD-O14	2618566	2/20/2018	8:12	2/23/2018	8:12	Blank	0.1 pCi/L	
AD-O16	2618622	2/20/2018	8:12	2/23/2018	7:28	D	1.3 pCi/L	226
AD-O17	2621495	2/20/2018	8:13	2/23/2018	7:32	D	0.7 pCi/L	187
AD-O17	2622288	2/20/2018	8:56	2/23/2018	8:56	Spike	9.4 pCi/L	
AD-O18	2618402	2/20/2018	0815	2/23/2018	7:32	D	0.9 pCi/L	185
AD-CONF-21	2618596	2/20/2018	8:15	2/23/2018	7:39	D	1.1pCi/L	1365
AD-O23	2618637	2/20/2018	8:17	2/23/2018	7:25	D	0.8 pCi/L	220
AD-O23	2618403	2/20/2018	8:17	2/23/2018	7:25	Blank	0.1 pCi/L	
AD-O24	2622245	2/20/2018	8:19	2/23/2018	7:43	D	1.2 pCi/L	242
AD-O25	2618635	2/20/2018	8:22	2/23/2018	7:26	D	1.0 pCi/L	111
AD-O25	2618404	2/20/2018	8:22	2/23/2018	7:26	Duplicate	1.0 pCi/L	
AD-CONF-60	2621290	2/20/2018	8:22	2/23/2018	7:27	D	1.0 pCi/L	574
AD-BR-62	2618577	2/20/2018	8:22	2/23/2018	7:27	D	1.5 pCi/L	279



Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: Administration Building
Test Location: 195 Southwest 3rd Avenue
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2618402
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-018
Radon Level : 0.9 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:15
Test Stop : 02/23/2018 @ 07:32
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 12:58

Canister ID# : 2618403
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-23-Blank
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:17
Test Stop : 02/23/2018 @ 07:25
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 12:41

Canister ID# : 2618404
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-025
Radon Level : 1.0 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:22
Test Stop : 02/23/2018 @ 07:26
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 12:58

Canister ID# : 2618422
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-05
Radon Level : 1.1 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:03
Test Stop : 02/23/2018 @ 07:35
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 11:27

Canister ID# : 2618428
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-01
Radon Level : 1.1 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:00
Test Stop : 02/23/2018 @ 07:27
Received: 02/26/2018 @ 12:10
Analyzed: 02/27/2018 @ 17:25

Canister ID# : 2618566
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-014-Blank
Radon Level : 0.1 pCi/L
Error for Measurement is: \pm 0.1 pCi/L
Test Start : 02/20/2018 @ 08:12
Test Stop : 02/23/2018 @ 08:12
Received: 02/26/2018 @ 12:10
Analyzed: 02/27/2018 @ 17:06



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: Administration Building
Test Location: 195 Southwest 3rd Avenue
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2618577
Canister Type : Charcoal Canister 3 inch
Location : Bsmf-AD-BR-62
Radon Level : 1.5 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:22
Test Stop : 02/23/2018 @ 07:27
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 13:19

Canister ID# : 2618590
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-Conf-6
Radon Level : 1.2 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:01
Test Stop : 02/23/2018 @ 07:23
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 11:59

Canister ID# : 2618595
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-011
Radon Level : 1.4 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:06
Test Stop : 02/23/2018 @ 07:31
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 13:19

Canister ID# : 2618596
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-Conf-21
Radon Level : 1.1 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:15
Test Stop : 02/23/2018 @ 07:39
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 10:45

Canister ID# : 2618608
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-012
Radon Level : 0.8 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:05
Test Stop : 02/23/2018 @ 07:30
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 13:18

Canister ID# : 2618622
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-016
Radon Level : 1.3 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:12
Test Stop : 02/23/2018 @ 07:28
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 12:41



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: Administration Building
Test Location: 195 Southwest 3rd Avenue
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2618626
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-013
Radon Level : 0.9 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:10
Test Stop : 02/23/2018 @ 07:30
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 13:18

Canister ID# : 2618635
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-025
Radon Level : 1.0 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:22
Test Stop : 02/23/2018 @ 07:26
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 12:59

Canister ID# : 2618637
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-23
Radon Level : 0.8 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:17
Test Stop : 02/23/2018 @ 07:25
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 12:41

Canister ID# : 2621207
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-01
Radon Level : 1.1 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:00
Test Stop : 02/23/2018 @ 07:27
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 11:59

Canister ID# : 2621290
Canister Type : Charcoal Canister 3 inch
Location : Bsmt-AD-Conf-60
Radon Level : 1.0 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:22
Test Stop : 02/23/2018 @ 07:27
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 11:59

Canister ID# : 2621306
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-03
Radon Level : 1.0 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:01
Test Stop : 02/23/2018 @ 07:29
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 13:18



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: Administration Building
Test Location: 195 Southwest 3rd Avenue
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2621357
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-02
Radon Level : 0.8 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:01
Test Stop : 02/23/2018 @ 07:29
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 11:09

Canister ID# : 2621369
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-08
Radon Level : 1.2 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:04
Test Stop : 02/23/2018 @ 07:25
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 13:19

Canister ID# : 2621466
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-014
Radon Level : 1.2 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:12
Test Stop : 02/23/2018 @ 07:29
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 11:08

Canister ID# : 2621495
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-017
Radon Level : 0.7 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 02/20/2018 @ 08:13
Test Stop : 02/23/2018 @ 07:32
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 12:41

Canister ID# : 2622199
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-08
Radon Level : 0.8 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:04
Test Stop : 02/23/2018 @ 07:25
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 11:59

Canister ID# : 2622221
Canister Type : Charcoal Canister 3 inch
Location : Main-AD-04
Radon Level : 0.7 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 02/20/2018 @ 08:02
Test Stop : 02/23/2018 @ 07:34
Received: 02/26/2018 @ 12:10
Analyzed: 02/28/2018 @ 13:18



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: Administration Building
Test Location: 195 Southwest 3rd Avenue
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2622225 Test Start : 02/20/2018 @ 08:05
Canister Type : Charcoal Canister 3 inch Test Stop : 02/23/2018 @ 07:25
Location : Main-AD-09 Received: 02/26/2018 @ 12:10
Radon Level : 1.4 pCi/L Analyzed: 02/28/2018 @ 11:43
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2622245 Test Start : 02/20/2018 @ 08:19
Canister Type : Charcoal Canister 3 inch Test Stop : 02/23/2018 @ 07:43
Location : Main-AD-024 Received: 02/26/2018 @ 12:10
Radon Level : 1.2 pCi/L Analyzed: 02/28/2018 @ 12:58
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2622262 Test Start : 02/20/2018 @ 08:05
Canister Type : Charcoal Canister 3 inch Test Stop : 02/23/2018 @ 07:31
Location : Main-AD-010 Received: 02/26/2018 @ 12:10
Radon Level : 1.2 pCi/L Analyzed: 02/28/2018 @ 11:27
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2622288 Test Start : 02/20/2018 @ 08:56
Canister Type : Charcoal Canister 3 inch Test Stop : 02/23/2018 @ 08:56
Location : Main-AD-017 Received: 02/26/2018 @ 12:10
Radon Level : 9.4 pCi/L Analyzed: 02/28/2018 @ 11:43
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: Administration Building
Test Location: 195 Southwest 3rd Avenue
Ontario, OR 97914-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201