

Room description (per the floor plan)	Canister serial #	Date opened	Time opened	Date Closed	Time closed	Type of test D = detector kit	Test results	Square Feet	Radon Testing Contact:
AI-CR101	2618648	2/20/2018	6:15	2/23/2018	6:15	D	0.6 pCi/L	902	Radon Testing Team Bob Bennett  Doug Kaechele
AI-CR101	2618421	2/20/2018	6:15	2/23/2018	6:15	DUPLICATE	0.9 pCi/L		
AI-CR102	2618575	2/20/2018	6:20	2/23/2018	6:13	D	0.5 pCi/L	1043	
AI-CR102	2618585	2/20/2018	6:20	2/23/2018	6:20	BLANK	0.1 pCi/L		
AI-CR1	2621131	2/20/2018	6:25	2/23/2018	6:11	D	0.1 pCi/L	1015	
AI-CR2	2618573	2/20/2018	6:26	2/23/2018	6:09	D	0.1 pCi/L	1037	
AI-CR3	2618567	2/20/2018	6:28	2/23/2018	6:07	D	0.2 pCi/L	1009	
AI-CR4	2618574	2/20/2018	6:29	2/23/2018	6:08	D	0.4 pCi/L	945	
AI-CR13	2621355	2/20/2018	6:33	2/23/2018	6:04	D	1.0 pCi/L	388	
AI-O14	2621224	2/20/2018	6:35	2/23/2018	6:01	D	0.7 pCi/L	134	
AI-O14	2622008	2/20/2018	6:35	2/23/2018	6:01	DUPLICATE	1.2 pCi/L		
AI-CR16	2621135	2/20/2018	6:36	2/23/2018	6:00	D	1.5 pCi/L	603	
AI-O19	2618641	2/20/2018	6:40	2/23/2018	6:00	D	0.6 pCi/L	130	
AI-GYM18	2618650	2/20/2018	7:25	2/23/2018	5:57	D	1.1 pCi/L	2064	
AI-GYM18	2622269	2/20/2018	7:25	2/23/2018	5:57	D	0.8 pCi/L		
AI-GYM18	2622260	2/20/2018	8:56	2/23/2018	8:56	SPIKE	9		
AI-O21	2621367	2/20/2018	6:45	2/23/2018	5:48	D	0.4 pCi/L	90	
AI-O22	2621320	2/20/2018	6:46	2/23/2018	5:52	D	0.5 pCi/L	130	
AI-O23	2618654	2/20/2018	6:48	2/23/2018	5:51	D	0.8 pCi/L	167	
AI-O24	2618605	2/20/2018	6:50	2/23/2018	5:54	D	0.8 pCi/L	88	
AI-O24	2618623	2/20/2018	6:50	2/23/2018	5:54	DUPLICATE	0.8 pCi/L		
AI-BR25	2618636	2/20/2018	6:51	2/23/2018	5:50	D	0.4 pCi/L	501	
AI-CR-LAB6	2622271	2/20/2018	6:57	2/23/2018	5:42	D	0.4 pCi/L	665	
AI-CR-LAB66	2618584	2/20/2018	6:58	2/23/2018	5:39	D	0.7 pCi/L	955	
AI-CR5	2618423	2/20/2018	7:00	2/23/2018	5:40	D	0.8 pCi/L	1018	
AI-CR7	2621573	2/20/2018	7:02	2/23/2018	5:43	D	0.8 pCi/L	951	
AI-CR7	2621241	2/20/2018	7:02	2/23/2018	7:02	BLANK	0.1 pCi/L		
AI-CR8	2618586	2/20/2018	7:05	2/23/2018	5:26	D	0.4 pCi/L	671	
AI-CR8	2622181	2/20/2018	7:05	2/23/2018	5:26	DUPLICATE	0.2 pCi/L		
AI-CR9	2622274	2/20/2018	7:10	2/23/2018	5:33	D	0.4 pCi/L	1012	
AI-CR9	2618603	2/20/2018	7:10	2/23/2018	7:10	BLANK	0.1 pCi/L		
AI-CR10	2622232	2/20/2018	7:13	2/23/2018	5:31	D	0.2 pCi/L	1013	
AI-CR11	2621445	2/20/2018	7:15	2/23/2018	5:36	D	0.3 pCi/L	940	
AI-CR12	2621453	2/20/2018	7:17	2/23/2018	5:30	D	0.6 pCi/L	946	
AI-CR12	2622286	2/20/2018	8:56	2/23/2018	8:56	SPIKE	8.2 pCi/L		
AI-CR27	2622277	2/20/2018	7:20	2/23/2018	5:23	D	0.4 pCi/L	673	

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Aiken Elementary  
Test Location: 1297 West Idaho Avenue  
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2618421  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR101  
Radon Level : 0.9 pCi/L  
Error for Measurement is:  $\pm$  0.3 pCi/L  
Test Start : 02/20/2018 @ 06:15  
Test Stop : 02/23/2018 @ 06:15  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 11:59

Canister ID# : 2618423  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR5  
Radon Level : 0.8 pCi/L  
Error for Measurement is:  $\pm$  0.4 pCi/L  
Test Start : 02/20/2018 @ 07:00  
Test Stop : 02/23/2018 @ 05:40  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 11:59

Canister ID# : 2618567  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR3  
Radon Level : 0.2 pCi/L  
Error for Measurement is:  $\pm$  0.2 pCi/L  
Test Start : 02/20/2018 @ 06:28  
Test Stop : 02/23/2018 @ 06:07  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 11:09

Canister ID# : 2618573  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR2  
Radon Level : 0.1 pCi/L  
Error for Measurement is:  $\pm$  0.5 pCi/L  
Test Start : 02/20/2018 @ 06:26  
Test Stop : 02/23/2018 @ 06:09  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/27/2018 @ 17:25

Canister ID# : 2618574  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR4  
Radon Level : 0.4 pCi/L  
Error for Measurement is:  $\pm$  0.4 pCi/L  
Test Start : 02/20/2018 @ 06:29  
Test Stop : 02/23/2018 @ 06:08  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 13:18

Canister ID# : 2618575  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR102  
Radon Level : 0.5 pCi/L  
Error for Measurement is:  $\pm$  0.3 pCi/L  
Test Start : 02/20/2018 @ 06:20  
Test Stop : 02/23/2018 @ 06:13  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/27/2018 @ 17:25



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Aiken Elementary  
Test Location: 1297 West Idaho Avenue  
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2618584                      Test Start : 02/20/2018 @ 06:58  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:39  
Location : Main-A1-CR-Lab 66              Received: 02/26/2018 @ 12:09  
Radon Level : 0.7 pCi/L                      Analyzed: 02/28/2018 @ 11:43  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2618585                      Test Start : 02/20/2018 @ 06:20  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 06:20  
Location : Main-A1-CR102-Blank              Received: 02/26/2018 @ 12:09  
Radon Level : 0.1 pCi/L                      Analyzed: 02/28/2018 @ 11:43  
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2618586                      Test Start : 02/20/2018 @ 07:05  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:26  
Location : Main-A1-CR8                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.4 pCi/L                      Analyzed: 02/27/2018 @ 18:30  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2618603                      Test Start : 02/20/2018 @ 07:10  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 07:10  
Location : Main-A1-CR 9-Blank              Received: 02/26/2018 @ 12:09  
Radon Level : 0.1 pCi/L                      Analyzed: 02/28/2018 @ 11:08  
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2618605                      Test Start : 02/20/2018 @ 06:50  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:54  
Location : Main-A1-024                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.8 pCi/L                      Analyzed: 02/28/2018 @ 11:59  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2618623                      Test Start : 02/20/2018 @ 06:50  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:54  
Location : Main-A1-024                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.8 pCi/L                      Analyzed: 02/28/2018 @ 12:41

Average of Side by Side Canisters              0.8 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Aiken Elementary  
Test Location: 1297 West Idaho Avenue  
Ontario, OR 97914-

Individual Canister Results

Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2618636  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-BR25  
Radon Level : 0.4 pCi/L  
Error for Measurement is: ± 0.4 pCi/L

Test Start : 02/20/2018 @ 06:51  
Test Stop : 02/23/2018 @ 05:50  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 12:59

Canister ID# : 2618641  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-019  
Radon Level : 0.6 pCi/L  
Error for Measurement is: ± 0.4 pCi/L

Test Start : 02/20/2018 @ 06:40  
Test Stop : 02/23/2018 @ 06:00  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 11:43

Canister ID# : 2618648  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR101  
Radon Level : 0.6 pCi/L  
Error for Measurement is: ± 0.4 pCi/L

Test Start : 02/20/2018 @ 06:15  
Test Stop : 02/23/2018 @ 06:15  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 12:41

Canister ID# : 2618650  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-Gym 18  
Radon Level : 1.1 pCi/L  
Error for Measurement is: ± 0.4 pCi/L

Test Start : 02/20/2018 @ 07:25  
Test Stop : 02/23/2018 @ 05:57  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 12:59

Canister ID# : 2618654  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-023  
Radon Level : 0.8 pCi/L  
Error for Measurement is: ± 0.4 pCi/L

Test Start : 02/20/2018 @ 06:48  
Test Stop : 02/23/2018 @ 05:51  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 11:09

Canister ID# : 2621131  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR1  
Radon Level : 0.1 pCi/L  
Error for Measurement is: ± 2.7 pCi/L

Test Start : 02/20/2018 @ 06:25  
Test Stop : 02/23/2018 @ 06:11  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 13:18



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Aiken Elementary  
Test Location: 1297 West Idaho Avenue  
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2621135  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR16  
Radon Level : 1.5 pCi/L  
Error for Measurement is:  $\pm$  0.3 pCi/L  
Test Start : 02/20/2018 @ 06:36  
Test Stop : 02/23/2018 @ 06:00  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 11:09

Canister ID# : 2621211  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR7-Blank  
Radon Level : 0.1 pCi/L  
Error for Measurement is:  $\pm$  0.6 pCi/L  
Test Start : 02/20/2018 @ 07:02  
Test Stop : 02/23/2018 @ 07:02  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 12:41

Canister ID# : 2621224  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-014  
Radon Level : 0.7 pCi/L  
Error for Measurement is:  $\pm$  0.3 pCi/L  
Test Start : 02/20/2018 @ 06:35  
Test Stop : 02/23/2018 @ 06:01  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/27/2018 @ 17:25

Canister ID# : 2621320  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-022  
Radon Level : 0.5 pCi/L  
Error for Measurement is:  $\pm$  0.3 pCi/L  
Test Start : 02/20/2018 @ 06:46  
Test Stop : 02/23/2018 @ 05:52  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 12:41

Canister ID# : 2621355  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-CR13  
Radon Level : 1.0 pCi/L  
Error for Measurement is:  $\pm$  0.3 pCi/L  
Test Start : 02/20/2018 @ 06:33  
Test Stop : 02/23/2018 @ 06:04  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 11:59

Canister ID# : 2621367  
Canister Type : Charcoal Canister 3 inch  
Location : Main-A1-021  
Radon Level : 0.4 pCi/L  
Error for Measurement is:  $\pm$  0.4 pCi/L  
Test Start : 02/20/2018 @ 06:45  
Test Stop : 02/23/2018 @ 05:48  
Received: 02/26/2018 @ 12:09  
Analyzed: 02/28/2018 @ 13:19



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Aiken Elementary  
Test Location: 1297 West Idaho Avenue  
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2621445                      Test Start : 02/20/2018 @ 07:15  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:36  
Location : Main-A1-CR 11                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.3 pCi/L                      Analyzed: 02/28/2018 @ 12:41  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2621453                      Test Start : 02/20/2018 @ 07:17  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:30  
Location : Main-A1-CR 12                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.6 pCi/L                      Analyzed: 02/27/2018 @ 18:30  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2621573                      Test Start : 02/20/2018 @ 07:02  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:43  
Location : Main-A1-CR7                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.8 pCi/L                      Analyzed: 02/28/2018 @ 12:41  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2622008                      Test Start : 02/20/2018 @ 06:35  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 06:01  
Location : Main-A1-014                      Received: 02/26/2018 @ 12:09  
Radon Level : 1.2 pCi/L                      Analyzed: 02/28/2018 @ 11:43  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2622181                      Test Start : 02/20/2018 @ 07:05  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:26  
Location : Main-A1-CR8                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.2 pCi/L                      Analyzed: 02/28/2018 @ 12:58  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2622232                      Test Start : 02/20/2018 @ 07:13  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:31  
Location : Main-A1-CR 10                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.2 pCi/L                      Analyzed: 02/28/2018 @ 11:59  
Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Aiken Elementary  
Test Location: 1297 West Idaho Avenue  
Ontario, OR 97914-

### Individual Canister Results

Canister ID# : 2622260                      Test Start : 02/20/2018 @ 08:56  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 08:56  
Location : Main-A1-Gym 18                      Received: 02/26/2018 @ 12:09  
Radon Level : 9.0 pCi/L                        Analyzed: 02/28/2018 @ 11:27  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2622269                      Test Start : 02/20/2018 @ 07:25  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:57  
Location : Main-A1-Gym 18                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.8 pCi/L                        Analyzed: 02/27/2018 @ 17:06  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2622271                      Test Start : 02/20/2018 @ 06:57  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:42  
Location : Main-A1-CR-Lab 6                    Received: 02/26/2018 @ 12:09  
Radon Level : 0.4 pCi/L                        Analyzed: 02/28/2018 @ 12:41  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2622274                      Test Start : 02/20/2018 @ 07:10  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:33  
Location : Main-A1-CR 9                        Received: 02/26/2018 @ 12:09  
Radon Level : 0.4 pCi/L                        Analyzed: 02/27/2018 @ 17:25  
Error for Measurement is:  $\pm$  0.2 pCi/L

Canister ID# : 2622277                      Test Start : 02/20/2018 @ 07:20  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 05:23  
Location : Main-A1-CR 27                      Received: 02/26/2018 @ 12:09  
Radon Level : 0.4 pCi/L                        Analyzed: 02/28/2018 @ 11:09  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2622286                      Test Start : 02/20/2018 @ 08:56  
Canister Type : Charcoal Canister 3 inch      Test Stop : 02/23/2018 @ 08:56  
Location : Main-A1-CR 12                      Received: 02/26/2018 @ 12:09  
Radon Level : 8.2 pCi/L                        Analyzed: 02/27/2018 @ 18:30  
Error for Measurement is:  $\pm$  0.4 pCi/L



*Andreas C. George*

*Dante Galan*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 02/26/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Aiken Elementary  
Test Location: 1297 West Idaho Avenue  
Ontario, OR 97914-

**Individual Canister Results**

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction ([www.epa.gov/radon/pdfs/consguid.pdf](http://www.epa.gov/radon/pdfs/consguid.pdf)) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at [www.epa.gov/iaq/radon](http://www.epa.gov/iaq/radon).

**For New Jersey clients:** Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

**For New York clients:** If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

---

**PLEDGE OF ASSURED QUALITY**

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or it's consultants based on RTCA-provided results.



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201