

Room description (per the floor plan)	Canister serial #	Date opened	Time opened	Date Closed	Time closed	Type of test D = detector kit	Test results	Square Feet	Radon Testing Contact:
AL-CR1	2622192	2/26/2018	0858	3/1/2018	0803	D	0.1	1042	Andrea Buchholz
AL-CR1	2618561	2/26/2018	0858	3/1/2018	0803	DUPLICATE	0.3		Radon Testing
AL-CR2	2622238	2/26/2018	0858	3/1/2018	0803	D	0.6	1046	Bob Bennett
AL-CR3	2618643	2/26/2018	0859	3/1/2018	0804	D	0.7	1044	John Martinez
AL-CR4	2621280	2/26/2018	0900	3/1/2018	0801	D	0.3	1037	Doug Kaechele
AL-CR5	2622242	2/26/2018	0904	3/1/2018	0802	D	0.6	884	
AL-CR6	2621266	2/26/2018	0904	3/1/2018	0802	D	0.4	884	
AL-CR7	2622213	2/26/2018	0904	3/1/2018	0801	D	0.2	883	
AL-CR7	2618425	2/26/2018	0904	3/1/2018	0742	BLANK	0.2		
AL-CR8	2618653	2/26/2018	0906	3/1/2018	0805	D	0.4	887	
AL-CR8	2618591	2/26/2018	0906	3/1/2018	0804	DUPLICATE	0.7		
AL-CR9	2618401	2/26/2018	0907	3/1/2018	0805	D	0.3	887	
AL-CR10	2618634	2/26/2018	0908	3/1/2018	0805	D	0.3	883	
AL-CR11	2621197	2/26/2018	0909	3/1/2018	0807	D	0.2	1047	
AL-CR12	2621151	2/26/2018	0910	3/1/2018	0807	D	0.4	1051	
AL-CR13	2618628	2/26/2018	0912	3/1/2018	0806	D	0.6	542	
AL-CR14	2618564	2/26/2018	0913	3/1/2018	0807	D	0.9	1044	
AL-LAB15	2618569	2/26/2018	0914	3/1/2018	0804	D	0.5	1789	
AL-CR16	2621255	2/26/2018	0914	3/1/2018	0806	D	0.4	489	
AL-CR17	2618655	2/26/2018	0838	3/1/2018	0749	D	0.1	1049	
AL-CR17	2622273	2/26/2018	0838	3/1/2018	0749	DUPLICATE	0.3		
AL-CR18	2622247	2/26/2018	0840	3/1/2018	0748	D	0.6	1041	
AL-CR18	2618587	2/26/2018	0840	3/1/2018	0747	BLANK	0.1		
AL-CR19	2622224	2/26/2018	0842	3/1/2018	0748	D	0.1	1053	
AL-CR20	2618658	2/26/2018	0839	3/1/2018	0749	D	0.4	1063	
AL-CR21	2618642	2/26/2018	0843	3/1/2018	0746	D	0.1	1048	
AL-CR22	2618629	2/26/2018	0844	3/1/2018	0747	D	0.4	1044	
AL-CR22	2621149	2/26/2018	0844	3/1/2018	0746	DUPLICATE	0.2		
AL-LAB23	2618430	2/26/2018	0845	3/1/2018	0744	D	0.4	1045	
AL-LIB24	2618439	2/26/2018	0845	3/1/2018	0744	D	0.1	1045	
AL-O27	2618646	2/26/2018	0915	3/1/2018	0803	D	1.3	178	
AL-BR28	2621191	2/26/2018	0916	3/1/2018	0810	D	0.8	173	
AL-O29	2618429	2/26/2018	0852	3/1/2018	0750	D	0.7	1398	
AL-O30	2618600	2/26/2018	0852	3/1/2018	0750	D	0.7	77	
AL-O31	2622223	2/26/2018	0852	3/1/2018	0749	D	0.5	128	
AL-GYM32	2618632	2/26/2018	0851	3/1/2018	0751	D	0.6	3929	
AL-GYM32	2618619	2/26/2018	0901	3/1/2018	0901	Spike	27.2		
AL-GYM32	2618400	2/26/2018	0851	3/1/2018	0751	D	0.7		
AL-BR34	2618562	2/26/2018	0837	3/1/2018	0745	D	0.5	263	



## Site Radon Inspection Report

Date : 03/05/2018

ATTN: Bob Bennett  
 ONTARIO SCHOOL DISTRICT 8 C  
 195 SW 3rd Avenue  
 Ontario, OR 97914-

Client: Alameda Elementary  
 Test Location: 1252 Alameda Drive  
 Ontario, OR 97914-

## Individual Canister Results

Canister ID# : 2618400                      Test Start : 02/26/2018 @ 08:51  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:51  
 Location : Main-AL-Gym 32                      Received: 03/05/2018 @ 15:33  
 Radon Level : 0.7 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
 Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2618401                      Test Start : 02/26/2018 @ 09:07  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:05  
 Location : Main-AL-CR 9                      Received: 03/05/2018 @ 15:33  
 Radon Level : 0.3 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
 Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2618425                      Test Start : 02/26/2018 @ 09:04  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:42  
 Location : Main-AL-CR 7-BLANK                  Received: 03/05/2018 @ 15:33  
 Radon Level : 0.2 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
 Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2618429                      Test Start : 02/26/2018 @ 08:52  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:50  
 Location : Main-AL-029                      Received: 03/05/2018 @ 15:33  
 Radon Level : 0.7 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
 Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2618430                      Test Start : 02/26/2018 @ 08:45  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:44  
 Location : Main-AL-LAB 23                      Received: 03/05/2018 @ 15:33  
 Radon Level : 0.4 pCi/L                      Analyzed: 03/08/2018 @ 12:45  
 Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2618439                      Test Start : 02/26/2018 @ 08:45  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:44  
 Location : Main-AL-LIB 24                      Received: 03/05/2018 @ 15:33  
 Radon Level : 0.1 pCi/L                      Analyzed: 03/08/2018 @ 11:17  
 Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*

Andreas C. George  
 Radon Measurement Specialist

NJ MES 11089

*Dante Galan*

Dante Galan  
 Laboratory Director

NRSB ARL0001  
 NYS ELAP ID: 10806  
 PADEP ID: 0346  
 NJDEP ID: NY933  
 NJ MEB 90036  
 FL DOH RB1609  
 IL RNL2000201



Site Radon Inspection Report

Date : 03/05/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Alameda Elementary  
Test Location: 1252 Alameda Drive  
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2618561                      Test Start : 02/26/2018 @ 08:58  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:03  
Location : Main-AL-CR1                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.3 pCi/L                      Analyzed: 03/08/2018 @ 12:27  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2618562                      Test Start : 02/26/2018 @ 08:37  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:45  
Location : Main-AL-BR-34                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.5 pCi/L                      Analyzed: 03/08/2018 @ 12:27  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2618564                      Test Start : 02/26/2018 @ 09:13  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:07  
Location : Main-AL-CR 14                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.9 pCi/L                      Analyzed: 03/08/2018 @ 12:27  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2618569                      Test Start : 02/26/2018 @ 09:14  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:04  
Location : Main-AL-LAB 15                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.5 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2618587                      Test Start : 02/26/2018 @ 08:40  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:47  
Location : Main-AL-CR 18-BLANK                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.1 pCi/L                      Analyzed: 03/08/2018 @ 12:45  
Error for Measurement is:  $\pm$  0.2 pCi/L

Canister ID# : 2618591                      Test Start : 02/26/2018 @ 09:06  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:05  
Location : Main-AL-CR 8                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.7 pCi/L                      Analyzed: 03/08/2018 @ 12:45  
Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*  
Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*  
Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 03/05/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Alameda Elementary  
Test Location: 1252 Alameda Drive  
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2618600                      Test Start : 02/26/2018 @ 08:52  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:50  
Location : Main-AL-030                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.7 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2618619                      Test Start : 02/26/2018 @ 09:01  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 09:01  
Location : Main-AL-Gym 32                      Received: 03/05/2018 @ 15:33  
Radon Level : 27.2 pCi/L                      Analyzed: 03/08/2018 @ 12:45  
Error for Measurement is:  $\pm$  1.0 pCi/L

Canister ID# : 2618628                      Test Start : 02/26/2018 @ 09:12  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:06  
Location : Main-AL-CR 13                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.6 pCi/L                      Analyzed: 03/08/2018 @ 11:17  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2618629                      Test Start : 02/26/2018 @ 08:44  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:47  
Location : Main-AL-CR 22                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.4 pCi/L                      Analyzed: 03/08/2018 @ 12:27  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2618632                      Test Start : 02/26/2018 @ 08:51  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:51  
Location : Main-AL-Gym 32                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.6 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2618634                      Test Start : 02/26/2018 @ 09:08  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:05  
Location : Main-AL-CR 10                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.3 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*  
Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*  
Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201





Site Radon Inspection Report

Date : 03/05/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Alameda Elementary  
Test Location: 1252 Alameda Drive  
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2621149                      Test Start : 02/26/2018 @ 08:44  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:47  
Location : Main-AL-CR 22                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.2 pCi/L                      Analyzed: 03/08/2018 @ 12:27  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2621151                      Test Start : 02/26/2018 @ 09:10  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:07  
Location : Main-AL-CR 12                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.4 pCi/L                      Analyzed: 03/08/2018 @ 12:45  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2621191                      Test Start : 02/26/2018 @ 09:16  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:10  
Location : Main-AL-BR 28                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.8 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2621197                      Test Start : 02/26/2018 @ 09:09  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:07  
Location : Main-AL-CR 11                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.2 pCi/L                      Analyzed: 03/08/2018 @ 12:27  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2621255                      Test Start : 02/26/2018 @ 09:14  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:06  
Location : Main-AL-CR 16                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.4 pCi/L                      Analyzed: 03/08/2018 @ 12:27  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2621266                      Test Start : 02/26/2018 @ 09:04  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:02  
Location : Main-AL-CR 6                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.4 pCi/L                      Analyzed: 03/08/2018 @ 13:03  
Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*  
Andreas C. George  
Radon Measurement Specialist

NJ MES 11089

*Dante Galan*  
Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 03/05/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Alameda Elementary  
Test Location: 1252 Alameda Drive  
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2621280                      Test Start : 02/26/2018 @ 09:00  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:01  
Location : Main-AL-CR 4                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.3 pCi/L                      Analyzed: 03/08/2018 @ 12:27  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2622192                      Test Start : 02/26/2018 @ 08:58  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:03  
Location : Main-AL-CR1                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.1 pCi/L                      Analyzed: 03/08/2018 @ 12:45  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2622213                      Test Start : 02/26/2018 @ 09:04  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:01  
Location : Main-AL-CR 7                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.2 pCi/L                      Analyzed: 03/08/2018 @ 11:17  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2622223                      Test Start : 02/26/2018 @ 08:52  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:49  
Location : Main-AL-031                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.5 pCi/L                      Analyzed: 03/08/2018 @ 12:45  
Error for Measurement is:  $\pm$  0.6 pCi/L

Canister ID# : 2622224                      Test Start : 02/26/2018 @ 08:42  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 07:48  
Location : Main-AL-CR 19                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.1 pCi/L                      Analyzed: 03/08/2018 @ 12:09  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2622238                      Test Start : 02/26/2018 @ 08:58  
Canister Type : Charcoal Canister 3 inch      Test Stop : 03/01/2018 @ 08:03  
Location : Main-AL-CR2                      Received: 03/05/2018 @ 15:33  
Radon Level : 0.6 pCi/L                      Analyzed: 03/08/2018 @ 12:09  
Error for Measurement is:  $\pm$  0.5 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist

NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 03/05/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Alameda Elementary  
Test Location: 1252 Alameda Drive  
Ontario, OR 97914-

Individual Canister Results

Canister ID# :	2622242	Test Start :	02/26/2018 @ 09:04
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/01/2018 @ 08:02
Location :	Main-AL-CR 5	Received:	03/05/2018 @ 15:33
Radon Level :	0.6 pCi/L	Analyzed:	03/08/2018 @ 13:21
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2622247	Test Start :	02/26/2018 @ 08:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/01/2018 @ 07:48
Location :	Main-AL-CR 18	Received:	03/05/2018 @ 15:33
Radon Level :	0.6 pCi/L	Analyzed:	03/08/2018 @ 13:03
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2622273	Test Start :	02/26/2018 @ 08:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/01/2018 @ 07:49
Location :	Main-AL-CR 17	Received:	03/05/2018 @ 15:33
Radon Level :	0.3 pCi/L	Analyzed:	03/08/2018 @ 12:45
Error for Measurement is: ±	0.4 pCi/L		

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction ([www.epa.gov/radon/pdfs/consguid.pdf](http://www.epa.gov/radon/pdfs/consguid.pdf)) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at [www.epa.gov/iaq/radon](http://www.epa.gov/iaq/radon).

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.



*Andreas C. George*  
Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*  
Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201





Site Radon Inspection Report

Date : 03/05/2018

ATTN: Bob Bennett  
ONTARIO SCHOOL DISTRICT 8 C  
195 SW 3rd Avenue  
Ontario, OR 97914-

Client: Alameda Elementary  
Test Location: 1252 Alameda Drive  
Ontario, OR 97914-  
Individual Canister Results

---

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or it's consultants based on RTCA-provided results.



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist

NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

(914)345-3380  
FAX (914)345-8546

2 Hayes Street, Elmsford, NY 10523  
www.rtca.com