

Ontario School District May Roberts Elementary
590 NW 8th St Ontario OR 97914

Room description (per the floor plan)	Canister serial #	Date opened	Time opened	Date Closed	Time closed	Type of test D = detector kit	Test results	Square Feet	Radon Testing Contact:
MR-CR101	2727217	1/28/2019	6:00	1/31/2019	6:08	D	1.0 pCi/L	493	Radon Testing Team Bob Bennett John Martinez Doug Kaechele
MR-LAB102	2727237	1/28/2019	6:00	1/31/2019	6:08	D	1.3 pCi/L	646	
MR-LIB103	2727242	1/28/2019	6:06	1/31/2019	6:07	D	1.3 pCi/L	1273	
MR-CR107	2727255	1/28/2019	6:02	1/31/2019	6:11	D	1.1 pCi/L	899	
MR-CR108	2727270	1/28/2019	6:03	1/31/2019	6:11	D	1.0 pCi/L	987	
MR-CR109	2727348	1/28/2019	6:02	1/31/2019	6:08	D	1.0 pCi/L	986	
MR-CR110	2727178	1/28/2019	6:03	1/31/2019	6:09	D	0.9 pCi/L	987	
MR-CR113	2727184	1/28/2019	6:04	1/31/2019	6:10	D	0.8 pCi/L	1015	
MR-CR114	2727228	1/28/2019	6:06	1/31/2019	6:09	D	1.0 pCi/L	1008	
MR-CR114	2727263	1/28/2019	6:06	1/28/2019	6:06	BLANK	0.2 pCi/L		
MR-CR118	2727324	1/28/2019	6:05	1/31/2019	6:08	D	0.8 pCi/L	1007	
MR-CR119	2727524	1/28/2019	6:06	1/31/2019	6:08	D	0.8 pCi/L	1008	
MR-CR120	2727222	1/28/2019	6:08	1/31/2019	6:10	D	1.2 pCi/L	1009	
MR-CR121	2727243	1/28/2019	6:09	1/31/2019	6:10	D	1.4 pCi/L	1009	
MR-CR121	2727341	1/28/2019	6:10	1/31/2019	6:10	DUPLICATE	1.1 pCi/L		
MR-CR201	2727347	1/28/2019	6:10	1/31/2019	6:18	D	1.3 pCi/L	1012	
MR-CR202	2727427	1/28/2019	6:11	1/31/2019	6:18	D	1.2 pCi/L	1004	
MR-CR203	2727503	1/28/2019	6:13	1/31/2019	6:19	D	1.2 pCi/L	1004	
MR-CR204	2727182	1/28/2019	6:14	1/31/2019	6:18	D	0.8 pCi/L	1004	
MR-CR205	2727220	1/28/2019	6:15	1/31/2019	6:16	D	1.4 pCi/L	1004	
MR-CR205	2727227	1/28/2019	6:15	1/28/2019	6:16	BLANK	0.1 pCi/L		
MR-CR206	2727251	1/28/2019	6:17	1/31/2019	6:17	D	1.2 pCi/L	1004	
MR-CR206	2727331	1/28/2019	6:17	1/31/2019	6:17	DUPLICATE	1.1 pCi/L		
MR-CR207	2727519	1/28/2019	6:18	1/31/2019	6:15	D	1.0 pCi/L	922	
MR-CR208	2727200	1/28/2019	6:16	1/31/2019	6:15	D	0.9 pCi/L	905	
MR-CR209	2727504	1/28/2019	6:15	1/31/2019	6:15	D	1.2 pCi/L	905	
MR-CR209	2727247	1/27/2019	8:26	1/30/2019	8:26	SPIKE	29.4 pCi/L		

Ontario School District May Roberts Elementary
590 NW 8th St Ontario OR 97914

Room description (per the floor plan)	Canister serial #	1/28/2019	Time opened	Date Closed	Time closed	Type of test D = detector kit	Test results	Square Feet
MR-CR210	2735507	1/28/2019	6:14	1/31/2019	6:14	D	1.2 pCi/L	984
MR-LAB211	2736081	1/28/2019	6:19	1/31/2019	6:13	D	0.8 pCi/L	510
MR-CR212	2736410	1/28/2019	6:19	1/31/2019	6:14	D	0.8 pCi/L	1179
MR-CR212	2727257	1/28/2019	6:19	1/31/2019	6:16	DUPLICATE	1.1 pCi/L	
MR-O300	2735790	1/28/2019	6:21	1/31/2019	6:24	D	1.0 pCi/L	488
MR-O301	2736400	1/28/2019	6:22	1/31/2019	6:23	D	1.2 pCi/L	94
MR-O302	2736414	1/28/2019	6:23	1/31/2019	6:23	D	0.8 pCi/L	145
MR-O304	2736408	1/28/2019	6:24	1/31/2019	6:25	D	0.8 pCi/L	70
MR-O305	2736512	1/28/2019	6:27	1/31/2019	6:27	D	1.0 pCi/L	95
MR-CONF307	2727225	1/28/2019	6:25	1/31/2019	6:24	D	0.7 pCi/L	158
MR-BR308	2727256	1/28/2019	6:26	1/31/2019	6:28	D	1.0 pCi/L	409
MR-BR308	2727289	1/28/2019	6:26	1/31/2019	6:28	DUPLICATE	1.0 pCi/L	
MR-CAF310	2735299	1/28/2019	6:28	1/31/2019	6:26	D	1.0 pCi/L	1268
MR-GYM311	2736504	1/28/2019	6:30	1/31/2019	6:26	D	1.1 pCi/L	2338
MR-CR312	2736470	1/28/2019	6:28	1/31/2019	6:24	D	1.9 pCi/L	1452
MR-CR312	2736423	1/27/2019	8:26	1/30/2019	8:26	SPIKE	25.7 pCi/L	
MR-O313	2736463	1/28/2019	6:29	1/31/2019	6:30	D	1.6 pCi/L	154
MR-O314	2736533	1/28/2019	6:31	1/31/2019	6:13	D	1.6 pCi/L	157

Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: May Roberts E.S.
Test Location: 590 NW 8th Street
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2727178 Test Start : 01/28/2019 @ 06:03
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:09
Location : 1st FL = MR-CR-110 Received: 02/04/2019 @ 16:09
Radon Level : 0.9 pCi/L Analyzed: 02/05/2019 @ 16:25
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2727182 Test Start : 01/28/2019 @ 06:14
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:18
Location : 1st FL = MR-CR-204 Received: 02/04/2019 @ 16:09
Radon Level : 0.8 pCi/L Analyzed: 02/05/2019 @ 17:16
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2727184 Test Start : 01/28/2019 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:10
Location : 1st FL = MR-CR-113 Received: 02/04/2019 @ 16:09
Radon Level : 0.8 pCi/L Analyzed: 02/05/2019 @ 15:24
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2727200 Test Start : 01/28/2019 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:15
Location : 1st FL = MR-CR-208 Received: 02/04/2019 @ 16:09
Radon Level : 0.9 pCi/L Analyzed: 02/05/2019 @ 15:42
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2727217 Test Start : 01/28/2019 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:08
Location : 1st FL = MR-CR-101 Received: 02/04/2019 @ 16:09
Radon Level : 1.0 pCi/L Analyzed: 02/05/2019 @ 16:58
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2727220 Test Start : 01/28/2019 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:16
Location : 1st FL = MR-CR-205 Received: 02/04/2019 @ 16:09
Radon Level : 1.4 pCi/L Analyzed: 02/05/2019 @ 16:10
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: May Roberts E.S.
Test Location: 590 NW 8th Street
Ontario, OR 97914-

Individual Canister Results

Canister ID# :	2727222	Test Start :	01/28/2019 @ 06:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:10
Location :	1st FL = MR-CR-120	Received:	02/04/2019 @ 16:09
Radon Level :	1.2 pCi/L	Analyzed:	02/05/2019 @ 15:06
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2727225	Test Start :	01/28/2019 @ 06:25
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:24
Location :	1st FL = MR-CONF-307	Received:	02/04/2019 @ 16:09
Radon Level :	0.7 pCi/L	Analyzed:	02/05/2019 @ 16:28
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2727227	Test Start :	01/28/2019 @ 06:15
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:15
Location :	1st FL = MR-CR-205 BL	Received:	02/04/2019 @ 16:09
Radon Level :	0.1 pCi/L	Analyzed:	02/05/2019 @ 15:03
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2727228	Test Start :	01/28/2019 @ 06:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:09
Location :	1st FL = MR-CR-114	Received:	02/04/2019 @ 16:09
Radon Level :	1.0 pCi/L	Analyzed:	02/05/2019 @ 15:55
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2727237	Test Start :	01/28/2019 @ 06:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:08
Location :	1st FL = MR-LAB-102	Received:	02/04/2019 @ 16:09
Radon Level :	1.3 pCi/L	Analyzed:	02/05/2019 @ 15:39
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2727242	Test Start :	01/28/2019 @ 06:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:07
Location :	1st FL = MR-LIB-103	Received:	02/04/2019 @ 16:09
Radon Level :	1.3 pCi/L	Analyzed:	02/05/2019 @ 15:21
Error for Measurement is: ±	0.4 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: May Roberts E.S.
Test Location: 590 NW 8th Street
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2727243 Test Start : 01/28/2019 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:10
Location : 1st FL = MR-CR-121 Received: 02/04/2019 @ 16:09
Radon Level : 1.4 pCi/L Analyzed: 02/05/2019 @ 15:39
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2727247 Test Start : 01/27/2019 @ 08:26
Canister Type : Charcoal Canister 3 inch Test Stop : 01/30/2019 @ 08:26
Location : 1st FL = MR-CR-209 Received: 02/04/2019 @ 16:09
Radon Level : 29.4 pCi/L Analyzed: 02/05/2019 @ 15:54
Error for Measurement is: ± 0.9 pCi/L

Canister ID# : 2727251 Test Start : 01/28/2019 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:17
Location : 1st FL = MR-CR-206 Received: 02/04/2019 @ 16:09
Radon Level : 1.2 pCi/L Analyzed: 02/05/2019 @ 16:40
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2727255 Test Start : 01/28/2019 @ 06:02
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:11
Location : 1st FL = MR-CR-107 Received: 02/04/2019 @ 16:09
Radon Level : 1.1 pCi/L Analyzed: 02/05/2019 @ 17:01
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2727256 Test Start : 01/28/2019 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:28
Location : 1st FL = MR-BR-308 Received: 02/04/2019 @ 16:09
Radon Level : 1.0 pCi/L Analyzed: 02/05/2019 @ 16:25
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2727257 Test Start : 01/28/2019 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:16
Location : 1st FL = MR-CR-212 DP Received: 02/04/2019 @ 16:09
Radon Level : 1.1 pCi/L Analyzed: 02/05/2019 @ 15:39
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: May Roberts E.S.
Test Location: 590 NW 8th Street
Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2727263
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = MR-CR-114 BL
Radon Level : 0.2 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 01/28/2019 @ 06:06
Test Stop : 01/31/2019 @ 06:06
Received: 02/04/2019 @ 16:09
Analyzed: 02/05/2019 @ 17:13

Canister ID# : 2727270
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = MR-CR-108
Radon Level : 1.0 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 01/28/2019 @ 06:03
Test Stop : 01/31/2019 @ 06:11
Received: 02/04/2019 @ 16:09
Analyzed: 02/05/2019 @ 17:16

Canister ID# : 2727289
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = MR-BR-308 DP
Radon Level : 1.0 pCi/L
Error for Measurement is: \pm 0.3 pCi/L
Test Start : 01/28/2019 @ 06:26
Test Stop : 01/31/2019 @ 06:28
Received: 02/04/2019 @ 16:09
Analyzed: 02/05/2019 @ 15:03

Canister ID# : 2727324
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = MR-CR-118
Radon Level : 0.8 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 01/28/2019 @ 06:05
Test Stop : 01/31/2019 @ 06:08
Received: 02/04/2019 @ 16:09
Analyzed: 02/05/2019 @ 15:03

Canister ID# : 2727331
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = MR-CR-206 DP
Radon Level : 1.1 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 01/28/2019 @ 06:17
Test Stop : 01/31/2019 @ 06:17
Received: 02/04/2019 @ 16:09
Analyzed: 02/05/2019 @ 16:43

Canister ID# : 2727341
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = MR-CR-121 DP
Radon Level : 1.1 pCi/L
Error for Measurement is: \pm 0.4 pCi/L
Test Start : 01/28/2019 @ 06:10
Test Stop : 01/31/2019 @ 06:10
Received: 02/04/2019 @ 16:09
Analyzed: 02/05/2019 @ 16:40



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
 ONTARIO SCHOOL DISTRICT 8 C
 195 SW 3rd Avenue
 Ontario, OR 97914-

Client: May Roberts E.S.
 Test Location: 590 NW 8th Street
 Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2727347 Test Start : 01/28/2019 @ 06:10
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:18
 Location : 1st FL = MR-CR-201 Received: 02/04/2019 @ 16:09
 Radon Level : 1.3 pCi/L Analyzed: 02/05/2019 @ 16:43
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2727348 Test Start : 01/28/2019 @ 06:02
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:08
 Location : 1st FL = MR-CR-109 Received: 02/04/2019 @ 16:09
 Radon Level : 1.0 pCi/L Analyzed: 02/05/2019 @ 16:25
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2727427 Test Start : 01/28/2019 @ 06:11
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:18
 Location : 1st FL = MR-CR-202 Received: 02/04/2019 @ 16:09
 Radon Level : 1.2 pCi/L Analyzed: 02/05/2019 @ 15:54
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2727503 Test Start : 01/28/2019 @ 06:13
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:19
 Location : 1st FL = MR-CR-203 Received: 02/04/2019 @ 16:09
 Radon Level : 1.2 pCi/L Analyzed: 02/05/2019 @ 15:54
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2727504 Test Start : 01/28/2019 @ 06:15
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:15
 Location : 1st FL = MR-CR-209 Received: 02/04/2019 @ 16:09
 Radon Level : 1.2 pCi/L Analyzed: 02/05/2019 @ 17:16
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2727519 Test Start : 01/28/2019 @ 06:18
 Canister Type : Charcoal Canister 3 inch Test Stop : 01/31/2019 @ 06:15
 Location : 1st FL = MR-CR-207 Received: 02/04/2019 @ 16:09
 Radon Level : 1.0 pCi/L Analyzed: 02/05/2019 @ 15:39
 Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
 Radon Measurement Specialist

NJ MES 11089

Dante Galan

Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
 ONTARIO SCHOOL DISTRICT 8 C
 195 SW 3rd Avenue
 Ontario, OR 97914-

Client: May Roberts E.S.
 Test Location: 590 NW 8th Street
 Ontario, OR 97914-
 Individual Canister Results

Canister ID# :	2727524	Test Start :	01/28/2019 @ 06:06
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:08
Location :	1st FL = MR-CR-119	Received:	02/04/2019 @ 16:09
Radon Level :	0.8 pCi/L	Analyzed:	02/05/2019 @ 16:58
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2735299	Test Start :	01/28/2019 @ 06:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:26
Location :	1st FL = MR-CAF-310	Received:	02/04/2019 @ 16:09
Radon Level :	1.0 pCi/L	Analyzed:	02/05/2019 @ 15:06
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2735507	Test Start :	01/28/2019 @ 06:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:14
Location :	1st FL = MR-CR-210	Received:	02/04/2019 @ 16:09
Radon Level :	1.2 pCi/L	Analyzed:	02/05/2019 @ 15:39
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2735790	Test Start :	01/28/2019 @ 06:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:24
Location :	1st FL = MR-0-300	Received:	02/04/2019 @ 16:09
Radon Level :	1.0 pCi/L	Analyzed:	02/05/2019 @ 16:40
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2736081	Test Start :	01/28/2019 @ 06:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:13
Location :	1st FL = MR-LAB-211	Received:	02/04/2019 @ 16:09
Radon Level :	0.8 pCi/L	Analyzed:	02/05/2019 @ 16:43
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2736400	Test Start :	01/28/2019 @ 06:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:23
Location :	1st FL = MR-0-301	Received:	02/04/2019 @ 16:09
Radon Level :	1.2 pCi/L	Analyzed:	02/05/2019 @ 15:54
Error for Measurement is: ±	0.4 pCi/L		



Andreas C. George

Andreas C. George
 Radon Measurement Specialist
 NJ MES 11089

Dante Galan

Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
 ONTARIO SCHOOL DISTRICT 8 C
 195 SW 3rd Avenue
 Ontario, OR 97914-

Client: May Roberts E.S.
 Test Location: 590 NW 8th Street
 Ontario, OR 97914-

Individual Canister Results

Canister ID# : 2736408
 Canister Type : Charcoal Canister 3 inch
 Location : 1st FL = MR-0-304
 Radon Level : 0.8 pCi/L
 Error for Measurement is: \pm 0.4 pCi/L

Test Start : 01/28/2019 @ 06:24
 Test Stop : 01/31/2019 @ 06:25
 Received: 02/04/2019 @ 16:09
 Analyzed: 02/05/2019 @ 16:40

Canister ID# : 2736410
 Canister Type : Charcoal Canister 3 inch
 Location : 1st FL = MR-CR-212
 Radon Level : 0.8 pCi/L
 Error for Measurement is: \pm 0.4 pCi/L

Test Start : 01/28/2019 @ 06:19
 Test Stop : 01/31/2019 @ 06:14
 Received: 02/04/2019 @ 16:09
 Analyzed: 02/06/2019 @ 13:37

Canister ID# : 2736414
 Canister Type : Charcoal Canister 3 inch
 Location : 1st FL = MR-0-302
 Radon Level : 0.8 pCi/L
 Error for Measurement is: \pm 0.4 pCi/L

Test Start : 01/28/2019 @ 06:23
 Test Stop : 01/31/2019 @ 06:23
 Received: 02/04/2019 @ 16:09
 Analyzed: 02/05/2019 @ 17:13

Canister ID# : 2736423
 Canister Type : Charcoal Canister 3 inch
 Location : 1st FL = MR-CR-312
 Radon Level : 25.7 pCi/L
 Error for Measurement is: \pm 0.9 pCi/L

Test Start : 01/27/2019 @ 08:26
 Test Stop : 01/30/2019 @ 08:26
 Received: 02/04/2019 @ 16:09
 Analyzed: 02/05/2019 @ 17:01

Canister ID# : 2736463
 Canister Type : Charcoal Canister 3 inch
 Location : 1st FL = MR-0-313
 Radon Level : 1.6 pCi/L
 Error for Measurement is: \pm 0.4 pCi/L

Test Start : 01/28/2019 @ 06:29
 Test Stop : 01/31/2019 @ 06:30
 Received: 02/04/2019 @ 16:09
 Analyzed: 02/05/2019 @ 16:58

Canister ID# : 2736470
 Canister Type : Charcoal Canister 3 inch
 Location : 1st FL = MR-CR-312
 Radon Level : 1.9 pCi/L
 Error for Measurement is: \pm 0.4 pCi/L

Test Start : 01/28/2019 @ 06:28
 Test Stop : 01/31/2019 @ 06:24
 Received: 02/04/2019 @ 16:09
 Analyzed: 02/05/2019 @ 15:24



Andreas C. George

Andreas C. George
 Radon Measurement Specialist
 NJ MES 11089

Dante Galan

Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: May Roberts E.S.
Test Location: 590 NW 8th Street
Ontario, OR 97914-
Individual Canister Results

Canister ID# :	2736504	Test Start :	01/28/2019 @ 06:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:26
Location :	1st FL = MR-GYM-311	Received:	02/04/2019 @ 16:09
Radon Level :	1.1 pCi/L	Analyzed:	02/05/2019 @ 15:06
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2736512	Test Start :	01/28/2019 @ 06:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:27
Location :	1st FL = MR-0-305	Received:	02/04/2019 @ 16:09
Radon Level :	1.0 pCi/L	Analyzed:	02/05/2019 @ 16:10
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2736533	Test Start :	01/28/2019 @ 06:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	01/31/2019 @ 06:13
Location :	1st FL = MR-0-314	Received:	02/04/2019 @ 16:09
Radon Level :	1.6 pCi/L	Analyzed:	02/05/2019 @ 16:58
Error for Measurement is: ±	0.4 pCi/L		

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 02/04/2019

Mr. Robert Bennett
ONTARIO SCHOOL DISTRICT 8 C
195 SW 3rd Avenue
Ontario, OR 97914-

Client: May Roberts E.S.
Test Location: 590 NW 8th Street
Ontario, OR 97914-
Individual Canister Results

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or it's consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201