

## Water Testing Results - May Roberts Elementary

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Room #	Fixture ID #	Date Tested	Test Results
East Staff Restroom Faucet	104	21080400-003SF23A	2/7/2023	1.93
East Hall Left Drinking Fountain	104	21080400-004DW23A	2/7/2023	ND
East Hall Right Drinking Fountain	104	21080400-005DW23A	2/7/2023	ND
Classroom 107 Faucet	107	21080400-006CF23A	2/7/2023	4.24
Classroom 107 Drinking Fountain	107	21080400-007DW23A	2/7/2023	ND
Classroom 108 Faucet	108	21080400-008CF23A	2/7/2023	2.37
Classroom 108 Drinking Fountain	108	21080400-009DW23A	2/7/2023	1.1
Classroom 109 Faucet	109	21080400-010CF23A	2/7/2023	2.4
Classroom 109 Drinking fountain	109	21080400-011DW23A	2/7/2023	1.3
Classroom 110 Faucet	110	21080400-012CF23A	2/7/2023	4.45
Classroom 110 Drinking Fountain	110	21080400-013DW23A	2/7/2023	ND
East Boys Restroom Left Faucet	111	21080400-014BF23A	2/7/2023	3.72
East Boys Restroom 2nd Faucet	111	21080400-015BF23A	2/7/2023	2.93
East Boys Restroom 3rd Faucet	111	21080400-016BF23A	2/7/2023	2.2
East Boys Restroom 4th Faucet	111	21080400-017BF23A	2/7/2023	ND
East Boys Restroom Right Faucet	111	21080400-018BF23A	2/7/2023	4.97
East Girls Restroom Left Faucet	112	21080400-019BF23A	2/7/2023	3
East Girls Restroom 2nd Faucet	112	21080400-020BF23A	2/7/2023	2.1
East Girls Restroom 3rd Faucet	112	21080400-021BF23A	2/7/2023	5
East Girls Restroom 4th Faucet	112	21080400-022BF23A	2/7/2023	2.76
East Girls Restroom Right Faucet	112	21080400-023BF23A	2/7/2023	2.43
Classroom 113 Faucet	113	21080400-024CF23A	2/7/2023	3.75
Classroom 113 Drinking Fountain	113	21080400-025DW23A	2/7/2023	2.2
Classroom 114 Faucet	114	21080400-026CF23A	2/7/2023	ND
Classroom 114 Drinking Fountain	114	21080400-027DW23A	2/7/2023	ND
Classroom 118 Faucet	118	21080400-028CF23A	2/7/2023	1
Classroom 118 Drinking Fountain	118	21080400-029DW23A	2/7/2023	1.79
Classroom 119 Faucet	119	21080400-030CF23A	2/7/2023	1.17
Classroom 119 Drinking Fountain	119	21080400-031DW23A	2/7/2023	2.09
Classroom 120 Faucet	120	21080400-032CF23A	2/7/2023	ND

Classroom 120 Drinking Fountain	120	21080400-033DW23A	2/7/2023	1.77
Classroom 121 Faucet	121	21080400-034CF23A	2/7/2023	ND
Classroom 121 Drinking Fountain	121	21080400-035DW23A	2/7/2023	1.51
Classroom 201 Faucet	201	21080400-036CF23A	2/7/2023	2.56
Classroom 201 Drinking Fountain	201	21080400-037DW23A	2/7/2023	ND
Classroom 202 Faucet	202	21080400-038CF23A	2/7/2023	4.31
Classroom 202 Drinking Fountain	202	21080400-039DW23A	2/7/2023	1.02
West Boys Restroom Left Faucet	213	21080400-040BF23A	2/7/2023	ND
West Boys Restroom Center Faucet	213	21080400-041BF23A	2/7/2023	ND
West Boys Restroom Right Faucet	213	21080400-042BF23A	2/7/2023	1.66
West Girls Restroom Left Faucet	214	21080400-043BF23A	2/7/2023	2.24
West Girls Restroom Center Faucet	214	21080400-044BF23A	2/7/2023	1.24
West Girls Restroom Right Faucet	214	21080400-045BF23A	2/7/2023	ND
Classroom 203 Faucet	203	21080400-046CF23A	2/7/2023	1.1
Classroom 203 Drinking Fountain	203	21080400-047DW23A	2/7/2023	ND
Classroom 204 Faucet	204	21080400-048CF23A	2/7/2023	1.45
Classroom 204 Drinking Fountain	204	21080400-049DW23A	2/7/2023	ND
Classroom 205 Faucet	205	21080400-050CF23A	2/7/2023	1.33
Classroom 205 Drinking Fountain	205	21080400-051DW23A	2/7/2023	15.1 ppb
Classroom 206 Faucet	206	21080400-052CF23A	2/7/2023	ND
Classroom 206 Drinking Fountain	206	21080400-053Dw23A	2/7/2023	2.78
Classroom 207 Faucet	207	21080400-054CF23A	2/7/2023	1.21
Classroom 207 Drinking Fountain	207	21080400-055DW23A	2/7/2023	ND
Classroom 208 Faucet	208	21080400-056CF23A	2/7/2023	1.17
Classroom 208 Drinking Fountain	208	21080400-057Dw23A	2/7/2023	ND
South Hallway Left Drinking Fountain	216	21080400-058DW23A	2/7/2023	1.65
South Hallway Right Drinking Fountain	216	21080400-059DW23A	2/7/2023	2.49
South Mens Restroom Left Faucet	217	21080400-060BF23A	2/7/2023	5.76
South Mens Restroom Right Faucet	217	21080400-061BF23A	2/7/2023	2.82
South Womens Restroom Left Faucet	218	21080400-062BF23A	2/7/2023	5.26
South Womens Restroom Right Faucet	218	21080400-063BF23A	2/7/2023	2.61
Classroom 209 Faucet	209	21080400-064CF23A	2/7/2023	1.7
Classroom 209 Drinking Fountain	209	21080400-065DW23A	2/7/2023	ND
Classroom 210 Faucet	210	21080400-066CF23A	2/7/2023	3.66

Classroom 210 Drinking Fountain	210	21080400-067DW23A	2/7/2023	ND
Northwest Restroom Faucet	303	21080400-068BF23A	2/7/2023	ND
North Staff Lounge Faucet	308	21080400-069KF23A	2/7/2023	ND
Kitchen Left Faucet	309	21080400-070KF23A	2/7/2023	1.24
Kitchen Center Faucet	309	21080400-071KF23A	2/7/2023	1.04
Kitchen Right Faucet	309	21080400-072KF23A	2/7/2023	1.1
Common Area Drinking Fountain	310	21080400-073DW23A	2/7/2023	1.17
Classroom 312 Faucet	312	21080400-074CF23A	2/7/2023	1.66
Classroom 312 Drinking Fountain	312	21080400-075DW23A	2/7/2023	1.59
North Mens Restroom Faucet	315	21080400-076BF23A	2/7/2023	ND
North Womens Restroom Faucet	316	21080400-077BF23A	2/7/2023	1.26
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing				
<b>RETESTS</b>				
Classroom 205 Drinking Fountain	205	21080400-051DW23B	4/4/2023	2.08
ND = Non Detect - Lead level is below the set detection limits of 1 ppb				