

**Water Testing Results - Transitions Academy**  
**Action Level is 15 parts per billion (ppb)**

Fixture Location/Description	Room #	Fixture ID #	Date Tested	
Boys Restroom Faucet	RR	21080704-088BF23A	12/13/2023	1.4
Girls Restroom Faucet	RR	21080704-089BF23A	12/13/2023	1.6
Front Room Drinking Fountain	FR	21080704-090WB23A	12/13/2023	ND
Front Room Faucet	FR	21080704-096KF23A	12/13/2023	ND

**Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing**

RETESTS				

**ND = Non Detect - Lead level is below the set detection limits of 1 ppb**