

Water Testing Results - Middle School

Action Level is 15 parts per billion (ppb)

| Fixture Location/Description | Room # | Fixture ID # | Date Tested | Test Results |
|---------------------------------------|--------|--------------------------|-------------|--------------|
| Classroom 101 Faucet | 101 | 21080600-001CF23A | 12/15/2023 | 1.6 |
| Classroom 101 Drinking Fountain | 101 | 21080600-002DW23A | 12/15/2023 | 1.4 |
| Classroom 102 Faucet | 102 | 21080600-003CF23A | 12/15/2023 | 1 |
| Classroom 102 Drinking Fountain | 102 | 21080600-004DW23A | 12/14/2023 | ND |
| Classroom 103 Faucet | 103 | 21080600-005CF23A | 12/14/2023 | 1 |
| Classroom 104 Faucet | 104 | 21080600-006CF23A | 12/14/2023 | |
| Classroom 104 Faucet | 104 | 21080600-007CF23A | 12/14/2023 | ND |
| Classroom 105 Faucet | 105 | 21080600-008CF23A | 12/14/2023 | 1 |
| Classroom 105 Drinking Fountain | 105 | 21080600-009DW23A | 12/14/2023 | ND |
| Classroom 106 Faucet | 106 | 21080600-010CF23A | 12/14/2023 | ND |
| Classroom 106 Drinking Fountain | 106 | 21080600-011DW23A | 12/14/2023 | ND |
| Classroom 107 Faucet | 107 | 21080600-012CF23A | 12/14/2023 | ND |
| Classroom 107 Drinking Fountain | 107 | 21080600-013DW23A | 12/14/2023 | ND |
| Classroom 108 Faucet | 108 | 21080600-014CF23A | 12/14/2023 | ND |
| Classroom 108 Drinking Fountain | 108 | 21080600-015DW23A | 12/14/2023 | ND |
| Classroom 109 Faucet | 109 | 21080600-016CF23A | 12/14/2023 | ND |
| Classroom 109 Drinking Fountain | 109 | 21080600-115DW23A | 12/14/2023 | ND |
| Girls Restroom Faucet | 136 | 21080600-017BF23A | 12/14/2023 | 1.5 |
| Boys Restroom Faucet | 138 | 21080600-018BF23A | 12/14/2023 | 2.7 |
| Staff Lounge Faucet | 112 | 21080600-019SF23A | 12/14/2023 | ND |
| Staff Womens Restroom Faucet | 113 | <u>21080600-020BF23A</u> | 12/14/2023 | ND |
| Staff Mens Restroom Faucet | 114 | 21080600-021BF23A | 12/14/2023 | ND |
| Sick Room Restroom Faucet | 120 | 21080600-124BF23A | 12/14/2023 | ND |
| Sick Room Faucet | 121 | 21080600-022BF23A | 12/14/2023 | 2.3 |
| 1st Floor Left Drinking Fountain | 132 | 21080600-023DW23A | 12/14/2023 | ND |
| 1st Floor Right Drinking Fountain | 132 | 21080600-024DW23A | 12/14/2023 | ND |
| Girls Locker Room Office Faucet | 302 | 21080602-079BF23A | 12/14/2023 | 7.9 |
| Tiger Gym Drinking Fountain | 304 | 21080602-080DW23A | 12/14/2023 | ND |
| Girls Locker Room Left Faucet | 309 | 21080602-081BF23A | 12/14/2023 | 2.2 |
| Girls Locker Room 2nd Faucet | 309 | 21080602-082BF23A | 12/14/2023 | 1.9 |
| Girls Locker Room 3rd Faucet | 309 | 21080602-083BF23A | 12/14/2023 | 2.5 |
| Girls Locker Room Right Faucet | 309 | 21080602-084BF23A | 12/14/2023 | 1.8 |
| Boys Locker Room Office Faucet | 301 | 21080602-085BF23A | 12/14/2023 | 17.1 |
| Boys Locker Room Left Faucet | 307 | 21080602-086BF23A | 12/14/2023 | 2.6 |
| Boys Locker Room 2nd Faucet | 307 | 21080602-087BF23A | 12/14/2023 | 6.3 |
| Boys Locker Room 3rd Faucet | 307 | 21080602-088BF23A | 12/14/2023 | 4.9 |
| Boys Locker Room Right Faucet | 307 | 21080602-089BF23A | 12/14/2023 | 1.3 |
| Tiger Gym Girls Restroom Left Faucet | 310 | 21080602-090BF23A | 12/14/2023 | 2.2 |
| Tiger Gym Girls Restroom 2nd Faucet | 310 | 21080602-091BF23A | 12/14/2023 | 4.6 |
| Tiger Gym Girls Restroom 3rd Faucet | 310 | 21080602-092BF23A | 12/14/2023 | 5.5 |
| Tiger Gym Girls Restroom Right Faucet | 310 | 21080602-116BF23A | 12/14/2023 | 2.8 |
| Tiger Gym Boys Restroom Left Faucet | 311 | 21080602-093BF23A | 12/14/2023 | 2.5 |
| Tiger Gym Boys Restroom 2nd Faucet | 311 | 21080602-094BF23A | 12/14/2023 | 2 |
| Tiger Gym Boys Restroom 3rd Faucet | 311 | 21080602-095BF23A | 12/14/2023 | 2.1 |
| Tiger Gym Boys Restroom Right Faucet | 311 | 21080602-117BF23A | 12/14/2023 | 4.9 |
| Classroom 201 Faucet | 201 | 21080600-025CF23A | 12/14/2023 | 1.5 |
| Classroom 201 Drinking Fountain | 201 | 21080600-026DW23A | 12/14/2023 | ND |
| Classroom 202 Faucet | 202 | 21080600-027CF23A | 12/14/2023 | 1 |
| Classroom 202 Drinking Fountain | 202 | 21080600-028DW23A | 12/14/2023 | ND |
| Classroom 203 Faucet | 203 | 21080600-029CF23A | 12/14/2023 | 1.1 |
| Classroom 203 Drinking Fountain | 203 | 21080600-030DW23A | 12/14/2023 | ND |
| Classroom 204 Faucet | 204 | 21080600-031CF23A | 12/14/2023 | ND |
| Classroom 204 Drinking Fountain | 204 | 21080600-032DW23A | 12/14/2023 | ND |

| | | | | |
|--|-------|-------------------|------------|------|
| Classroom 205 Left Faucet | 205 | 21080600-033CF23A | 12/14/2023 | 4.5 |
| Classroom 205 2nd Faucet | 205 | 21080600-121CF23A | 12/14/2023 | 2.5 |
| Classroom 205 3rd Faucet | 205 | 21080600-122CF23A | 12/14/2023 | 3.2 |
| Classroom 205 Right Faucet | 205 | 21080600-123CF23A | 12/14/2023 | 1.4 |
| Classroom 206 Left Faucet | 206 | 21080600-034CF23A | 12/14/2023 | 3.7 |
| Classroom 206 2nd Faucet | 206 | 21080600-118CF23A | 12/14/2023 | 4 |
| Classroom 206 3rd Faucet | 206 | 2108600-119CF23A | 12/14/2023 | 4.4 |
| Classroom 206 Right Faucet | 206 | 2108600-120CF23A | 12/14/2023 | 3.8 |
| Classroom 206 Drinking Fountain | 206 | 21080600-035DW23A | 12/14/2023 | 4.9 |
| Staff Lounge Faucet | 216 | 21080600-036SF23A | 12/14/2023 | ND |
| 2nd Floor Womens Restroom Faucet | 217 | 21080600-037BF23A | 12/14/2023 | ND |
| 2nd Floor Mens Restroom Faucet | 217 | 21080600-038BF23A | 12/14/2023 | ND |
| 200 Hall Left Drinking Fountain | 200 | 21080600-039DW23A | 12/14/2023 | ND |
| 200 Hall Right Drinking Fountain | 200 | 21080600-040DW23A | 12/14/2023 | ND |
| Classroom 207 Left Faucet | 207 | 21080600-041CF23A | 12/14/2023 | 3.2 |
| Classroom 207 2nd Faucet | 207 | 21080600-127CF23A | 12/14/2023 | 2.7 |
| Classroom 207 3rd Faucet | 207 | 21080600-128CF23A | 12/14/2023 | 3.2 |
| Classroom 207 Right Faucet | 207 | 21080600-129CF23A | 12/14/2023 | 8.7 |
| Classroom 208 Faucet | 208 | 21080600-042CF23A | 12/14/2023 | ND |
| Classroom 208 Drinking Fountain | 208 | 21080600-043DW23A | 12/14/2023 | ND |
| Classroom 209 Faucet | 209 | 21080600-044CF23A | 12/14/2023 | 1.1 |
| Classroom 209 Drinking Fountain | 209 | 21080600-045DW23A | 12/14/2023 | ND |
| Classroom 210 Faucet | 210 | 21080600-046CF23A | 12/14/2023 | 1.2 |
| Classroom 210 Drinking Fountain | 210 | 21080600-047DW23A | 12/14/2023 | ND |
| Classroom 211 Faucet | 211 | 21080600-048CF23A | 12/14/2023 | ND |
| Classroom 211 Drinking Fountain | 211 | 21080600-049DW23A | 12/14/2023 | ND |
| Classroom 212 Faucet | 212 | 21080600-050CF23A | 12/14/2023 | 1.3 |
| Classroom 212 Drinking Fountain | 212 | 21080600-051DW23A | 12/14/2023 | ND |
| Classroom 213 Faucet | 213 | 21080600-052CF23A | 12/14/2023 | 1.1 |
| Classroom 213 Drinking Fountain | 213 | 21080600-053DW23A | 12/14/2023 | ND |
| 200 Hall Boys Handwash Station | 221 | 21080600-054BF23A | 12/14/2023 | 1.7 |
| 200 Hall Girls Handwash Station | 223 | 21080600-055BF23A | 12/14/2023 | 1.4 |
| Discovery SE Office faucet | D3 | 21080601-113SF23A | 12/14/2023 | 15.5 |
| Discovery Staff Lounge Faucet | D4 | 21080601-056KF23A | 12/14/2023 | ND |
| Discovery Staff Lounge Restroom Faucet | D4 RR | 21080601-114BF23A | 12/14/2023 | 1 |
| Discovery Hall Drinking Fountain | D14 | 21080601-057WB23A | 12/14/2023 | ND |
| Discovery Art Room Left Faucet | D16 | 21080601-058CF23A | 12/14/2023 | ND |
| Discovery Art Room 2nd Faucet | D16 | 21080601-059CF23A | 12/14/2023 | ND |
| Discovery Art Room 3rd Faucet | D16 | 21080601-060CF23A | 12/14/2023 | ND |
| Discovery Art Room 4th Faucet | D16 | 21080601-061CF23A | 12/14/2023 | ND |
| Discovery Art Room 5th Faucet | D16 | 21080601-062CF23A | 12/14/2023 | ND |
| Discovery Art Room Right Faucet | D16 | 21080601-063CF23A | 12/14/2023 | ND |
| Discovery Kitchen Left Faucet | D17 | 21080601-064KF23A | 12/14/2023 | ND |
| Discovery Kitchen 2nd Faucet | D17 | 21080601-065KF23A | 12/14/2023 | ND |
| Discovery Kitchen 3rd Faucet | D17 | 21080601-066SF23A | 12/14/2023 | 6.2 |
| Discovery Kitchen Right Faucet | D17 | 21080601-125KF23A | 12/14/2023 | 8.3 |
| Discovery Kitchen Staff Faucet | D31 | 21080601-067BF23A | 12/14/2023 | 1.5 |
| Discovery Commons Drinking Fountain | D21 | 21080601-068DW23A | 12/14/2023 | 1.7 |
| Discovery Old Art Room Left Faucet | D19 | 21080601-069CF23A | 12/14/2023 | 11.9 |
| Discovery Old Art Room 2nd Faucet | D19 | 21080601-070CF23A | 12/14/2023 | 316 |
| Discovery Old Art Room Right Faucet | D19 | 21080601-071CF23A | 12/14/2023 | 13.7 |
| Discovery Old Art Room Drinking Fountain | D19 | 21080601-072DW23A | 12/14/2023 | 6.4 |
| Discovery Boys Restroom Left Faucet | D28 | 21080601-073BF23A | 12/14/2023 | 1.3 |
| Discovery Boys Center Faucet | D28 | 21080601-074BF23A | 12/14/2023 | ND |
| Discovery Boys Right Faucet | D28 | 21080601-075BF23A | 12/14/2023 | 1 |
| Discovery Girls Left Faucet | D27 | 21080601-076BF23A | 12/14/2023 | 3 |
| Discovery Girls Center Faucet | D27 | 21080601-077BF23A | 12/14/2023 | ND |
| Discovery Gilrs Right Faucet | D27 | 21080601-078BF23A | 12/14/2023 | ND |

| | | | | |
|---------------------------------------|------|-------------------|------------|------|
| Odyssey Kitchen Left Faucet | O1 | 21080604-099KF23A | 12/14/2023 | ND |
| Odyssey Kitchen Right Faucet | O1 | 21080604-126KF23A | 12/14/2023 | 3.5 |
| Odyssey Kitchen Drinking Fountain | O1 | 21080604-100DW23A | 12/14/2023 | ND |
| Odyssey Classroom 2 Drinking Fountain | O2 | 21080604-102DW23A | 12/14/2023 | 8.8 |
| Odyssey Classroom 3 Faucet | O3 | 21080604-103CF23A | 12/14/2023 | 3 |
| Odyssey Classroom 3 Drinking Fountain | O3 | 21080604-104DW23A | 12/14/2023 | 4.1 |
| Odyssey Classroom 3 Restroom Faucet | O3 | 21080604-105BF23A | 12/14/2023 | ND |
| Odyssey Classroom 4 Faucet | O4 | 21080604-106CF23A | 12/14/2023 | 2.6 |
| Odyssey Classroom 5 Faucet | O5 | 21080604-107CF23A | 12/14/2023 | 2 |
| Odyssey Hall Drinking Fountain | Hall | 21080604-108DW23A | 12/14/2023 | ND |
| Odyssey Girls Restroom Left Faucet | RR | 21080604-109BF23A | 12/14/2023 | ND |
| Odyssey Girls Restroom Right Faucet | RR | 21080604-110BF23A | 12/14/2023 | 1 |
| Odyssey Boys Restroom Left Faucet | RR | 21080604-111BF23A | 12/14/2023 | ND |
| Odyssey Boys Restroom Right Faucet | RR | 21080604-112BF23A | 12/14/2023 | 11.8 |

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

| | | | | |
|--------------------------------------|-----|-------------------|-----------|-----|
| RETESTS | | | | |
| Odyssey Boys Restroom Right Faucet | RR | 21080604-112BF23B | 1/31/2024 | ND |
| Discovery SE Office Faucet | D3 | 21080601-113SF23B | 1/31/2024 | 1.9 |
| Boys Locker Room Office Faucet | 301 | 21080602-085BF23A | 1/31/2024 | 1.4 |
| Discovery Old Art Room Left Faucet | D19 | 21080601-069CF23B | 1/31/2024 | 4.7 |
| Discovery Old Art Room Center Faucet | D19 | 21080601-070CF23B | 1/31/2024 | 1.2 |
| Discovery Old Art Room Right Faucet | D19 | 21080601-071CF23B | 1/31/2024 | 6.5 |

ND = Non Detect - Lead level is below the set detection limits of 1 ppb