

Water Testing Results - Pioneer Elementary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Room #	Fixture ID #	Date Tested	Test Results
Classroom 0 Faucet	0	21080500-001CF23A	2/14/2023	3.42
Classroom 0 Drinking Fountain	0	21080500-002DW23A	2/14/2023	1.38
Classroom 1 Faucet	1	21080500-003CF23A	2/14/2023	1.56
Classroom 1 Drinking Fountain	1	21080500-004DW23A	2/14/2023	ND
Classroom 2 Faucet	2	21080500-005CF23A	2/14/2023	7.83
Classroom 2 Drinking Fountain	2	21080500-006DW23A	2/14/2023	1.52
Classroom 3 Faucet	3	21080500-007CF23A	2/14/2023	ND
Classroom 3 Drinking Fountain	3	21080500-008DW23A	2/14/2023	ND
Classroom 4 Faucet	4	21080500-009CF23A	2/14/2023	5.62
Classroom 4 Drinking Fountain	4	21080500-010DW23A	2/14/2023	ND
Classroom 5 Faucet	5	21080500-011CF23A	2/14/2023	2.36
Classroom 5 Drinking Fountain	5	21080500-012DW23A	2/14/2023	ND
Classroom 6 Faucet	6	21080500-013CF23A	2/14/2023	1.31
Classroom 6 Drinking Fountain	6	21080500-014DW23A	2/14/2023	ND
Basement Staff Lounge Faucet	11	21080500-015KF23A	2/14/2023	4.22
Basement Staff Lounge Restroom Faucet	11	21080500-016BF23A	2/14/2023	1.39
Gymnasium Drinking Fountain	15	21080500-017DW23A	2/14/2023	8.56
Kitchen Left Faucet	16	21080500-018KF23A	2/14/2023	3.04
Kitchen Center Faucet	16	21080500-019KF23A	2/14/2023	6.95
Kitchen Right Faucet	16	21080500-020SF23A	2/14/2023	15.8 ppb
South Boys Restroom Left Faucet	24	21080500-021BF23A	2/14/2023	ND
South Boys Restroom Center Faucet	24	21080500-022BF23A	2/14/2023	1.07
South Boys Restroom Right Faucet	24	21080500-023BF23A	2/14/2023	ND
South Drinking Fountain	24	21080500-024DW23A	2/14/2023	ND
South Girls Restroom Left Faucet	25	21080500-025BF23A	2/14/2023	1.69
South Girls Restroom Center Faucet	25	21080500-026BF23A	2/14/2023	1.11
South Girls Restroom Right Faucet	25	21080500-027BF23A	2/14/2023	1.36
Gymnasium Girls Restroom Faucet	28	21080500-028BF23A	2/14/2023	2.23
Gymnasium Boys Restroom Faucet	29	21080500-029BF23A	2/14/2023	4.31

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS				
Kitchen Right Faucet	16	21080500-020SF23B	4/4/2023	14.4
Kitchen Right Faucet	16	21080500-020SF	12/13/2023	ND

ND = Non Detect - Lead level is below the set detection limits of 1 ppb