

Water Testing Results - Warehouse
Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Room #	Fixture ID #	Date Tested	
Maint Shop Restroom Faucet	900	21080001-001BF23A	12/13/2023	1.2
Laundry Restroom Faucet	900	21080001-002BF23A	12/13/2023	ND
Maint Shop Drinking Fountain	900	21080001-003DW23A	12/13/2023	12.4
Laundry Shop Drinking Fountain	900	21080001-004DW23A	12/13/2023	7.1

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS				
Maint Shop Drinking Fountain	900	21080001-003DW23B	1/31/2024	ND

ND = Non Detect - Lead level is below the set detection limits of 1 ppb